



SANITATION DISTRICTS OF LOS ANGELES COUNTY

# **Los Angeles County Sanitation Districts' Odor Control Practices**



Robert Morton



Los Angeles County Sanitation Districts


# Organization of Presentation

- **Background of Los Angeles County Sanitation Districts**
- **Wastewater treatment information**
- **Odor control in collection system**
- **Odor control in wastewater treatment plants**



# Los Angeles County Sanitation Districts Wastewater Collection & Treatment System


| Symbol  | Description                          |
|---|--------------------------------------|
|  | 3 - Landfills                        |
|  | 11 - Treatment Plants                |
|  | 1,328 miles of regional trunk sewers |



# **Los Angeles County Sanitation Districts Wastewater Collection & Treatment System**

- **Treating 500 mgd of wastewater**
  - **200 mgd at 10 WRP**
  - **300 mgd at JWPCP**
- **2012-2013 operation budget ~\$565 M**


# Typical LACSD WRP Design



# 70 MGD of LACSD Secondary and Tertiary Effluents Are Reused




# LACSD Joint Water Pollution Control Plant (JWPCP)



# Odor Control in Collection Systems



# Hydrogen Sulfide is the Typically the Most Odorous Compound Generated in Sewers



# Compounds Other Than Hydrogen Sulfide That Could Contribute Collection System Odors


- **Sulfur compounds**
  - mercaptans, organic sulfides
- **Volatile Acids**
  - fatty and carboxylic acids
- **Nitrogen Compounds**
  - ammonia, amines, diamines

# Odor Chromatogram



# Example Odor Chromatogram

Geometric Mean Odor Chromatogram




# Testing Conducted at Los Angeles County Sanitation Districts




# LACSD Manhole MH18

Geometric Mean Odor Chromatogram Odor198



# LACSD Manhole MH18

Mass Spectrometric Chromatogram Scaled for Injection Volume, Dilution, and Instrument Response



# LACSD Manhole MH18

## Analysis for Fatty and Carboxylic Acids

| Compound       | Concentration<br>(ppb v/v) |
|----------------|----------------------------|
| Acetic Acid    | < 5.6                      |
| Propionic Acid | < 1.2                      |
| Isobutyric     | < 0.99                     |
| Butyric        | < 0.97                     |
| Isovalreic     | < 0.85                     |
| Valeric        | < 0.86                     |
| Caproic        | < 0.76                     |

# LACSD Manhole MH18

## Analysis Organic Nitrogen Compounds

| Compound       | Concentration<br>(ppb v/v) |
|----------------|----------------------------|
| Dimethylamine  | < 1.5                      |
| Ethylamine     | < 1.5                      |
| Trimethylamine | 1.4                        |
| Diethylamine   | < 0.89                     |
| Butylamine     | < 0.92                     |
| Triethylamine  | < 0.67                     |

# Methods for Controlling H<sub>2</sub>S in Collection Systems


- **Chemical addition**
  - **Preventers**
  - **Binders**
  - **Oxidizers**
  - **pH change**
- **Vapor phase treatment**
  - **Wet scrubbers**
  - **Activated carbon**
  - **Biological treatment**
- **Neutralize acid formation**

# Collection System Odor & Corrosion Control

- **Continuous ferrous chloride addition**
- **Sodium hydroxide (caustic) shock dosing**
- **Activated carbon scrubbing**
- **Mg(OH)<sub>2</sub> crown spray**

# Odor Control in Collection Systems

## Ferrous Chloride Addition



1986 Districts' Study

# Ferrous Chloride Addition

- **30,000 gpd of FeCl<sub>2</sub> added to collection system**
- **Maintain sewer headspace H<sub>2</sub>S to less than 20 ppm<sub>v/v</sub>**



# Ferrous Chloride Addition




Table 1—Collection System FeCl<sub>2</sub> Addition Locations and Amounts

| Addition Point             | Sewer | Percent Total | Approximately gallons per day* |
|----------------------------|-------|---------------|--------------------------------|
| San Jose Creek WRP         | JOB   | 53%           | 15,900                         |
| Whittier Narrows           | JOH   | 17%           | 5,100                          |
| South Gate                 | JOA   | 16%           | 4,800                          |
| Long Beach                 | JOC   | 9%            | 2,700                          |
| Beach Avenue Pumping Plant | JOD   | 5%            | 1,500                          |

\*Assuming 30,000 gpd total

**Annual cost of ~\$12 million**

# Caustic Shock Dosing



# Activated Carbon Scrubbing



# Activated Carbon Use Inside Manholes



**Carbon Canister**




**Manhole with Activated Carbon**

# Crown Spray Program

- **Crown Spray Process Developed by the Districts**
- **Magnesium Hydroxide: pH ~10**
- **Only RCP and NRCP Sewers With Moderate to Severe Corrosion**
- **420 Miles Crown Sprayed Annually**
- **Cost ~\$3 million/yr**

# Mg(OH)<sub>2</sub> Crown Spraying




# Odor Control in Wastewater Treatment Plants



# JWPCP Facility




# Population Encroachment Near JWPCP



| <b>Distance<br/>From<br/>Plant<br/>Boundary<br/>Miles</b> | <b>Total<br/>Population</b> |
|---|-----------------------------|
| <b>0.25</b>   | <b>10,100</b>               |
| <b>0.5</b>  | <b>26,100</b>               |
| <b>0.75</b>   | <b>48,700</b>               |
| <b>1.25</b>   | <b>93,500</b>               |

# JWPCP Odor Control Areas



# Joint Water Pollution Control Plant (JWPCP)




# Methods for Control of Odors from Wastewater Treatment Facilities

- **Chemical Treatment of Wastewater**
- **Thermal Destruction**
- **Wet Chemical Scrubbing**
- **Adsorption**
- **Biological**
  - **Biotrickling Filters**
  - **Biofilters**


# Chemical Addition for H<sub>2</sub>S Control



## Ferrous Chloride



Dissolved Sulfides < 0.2 mg/L



## Caustic Addition


pH > 9.0

# Air Process Stream Treatment

| Odor Control Alternative | Ability to Remove   |   |   | Track Record  | Flexibility   | Mechanical Equipment Intensive  | Residual By-Products  |
|--------------------------|---|---|---|---|---|---|---|
|                          | H <sub>2</sub> S  | Organic Sulfur Compounds  | Ammonia   |   |   |   |   |
| Thermal Destruction      |    |    |    |    |   |  |    |
| Wet-Scrubbing            |    |   |    |    |    |  |    |
| Carbon                   |  |  |   |  |   |   |  |
| Biofilter                |  |  |  |   |  |   |   |
| Biotrickling Filter      |  |   |   |  |   |   |   |




# Thermal Destruction

## Thermal/Catalytic Oxidization




- Basic Incineration technology, VOC's destroyed at high temperatures ( $>1400^{\circ}\text{F}$ )
- Generally achieves  $>95\%$  destruction efficiency.
- Consumes significant quantities of fuel (natural gas).
- Discharges  $\text{NO}_x$  and large quantities of  $\text{CO}_2$ .

# Caustic Packed Tower



# Activated Carbon Scrubber

CHANGEOUT BASED ON VOC  
BREAKTHROUGH



# Two-Stage Treatment

## Chemical Scrubbing and Activated Carbon



Caustic  
Scrubber

Carbon  
Scrubber



# **Biotrickling Filters or Bioscrubbers**


# Old and New Covers




# JWPCP Odor Control – Primary Treatment



# Los Angeles County Sanitation Districts' Lava Rock Biotrickling Filter Schematic




# Sulfur Oxidizing Bacteria



# Los Angeles County Sanitation Districts' 1500 cfm Biotrickling Filter




# Removal of Hydrogen Sulfide by LACSD Lava Rock Biotrickling Filter During the First Year of Operation



# **Some Basic Concepts Used in the Design of the JWPCP Central Odor Station**

- **Use a two-stage system to achieve maximum removal of odors**
- **Employ high ventilation rates to keep primary treatment areas under negative pressure**
- **Use of secondary treated effluent as a source of nutrients for biotrickling filters**
- **Design of redundant units to allow maintenance and repairs**

# JWPCP Central Odor Biotrickling Filters Process Flow Diagram



# Biotrickling Filters After Completion of Concrete Form Work



# **Two Stage Treatment of Air from Plant Headworks, Channels and Grit Chambers**


**60,000 cfm of foul air treatment**




# **Sedimentation Tank Odor Control Project**

- **Primary sedimentation tanks and the primary effluent channels**
- **Three (3) odor control stations**
- **Biotrickling and activated carbon scrubbers**
- **160,000 cfm total ventilation rate**

# Sedimentation Odor Control Station Process Flow Diagram




# Sedimentation Tank Odor Control Project




# Full-Scale Biotrickling Filter and Activated Carbon Design Criteria

| Odor Control Stations                    |  | E-1           | E-2           | E-3            | Central Odor  |
|--|--|---------------|---------------|----------------|---------------|
| <b>Biotrickling Filters' Information</b> | Shape                                    | Rectangular   | Rectangular   | Rectangular    | Cylindrical   |
|  | Media Depth (ft)                         | 12.5          | 12.5          | 12.5           | 12.5          |
|  | Media Volume (ft <sup>3</sup> ) / Vessel | 5,317         | 4,513         | 6,050          | 4,752         |
|  | Design EBRT (sec)                        | 14            | 14            | 14             | 14            |
|  | No. BTFs                                 | 1             | 2             | 4              | 3             |
| <b>Carbon Scrubbers' Information</b>     | Shape                                    | Rectangular   | Rectangular   | Rectangular    | Cylindrical   |
|  | Media Depth (ft)                         | 3             | 3             | 3              | 3             |
|  | Media Volume (ft <sup>3</sup> ) / Vessel | 1,323         | 1,134         | 2,523          | 1,473         |
|  | Vessel Height (ft)                       | 15            | 15            | 15             | 15            |
|  | No. of Units                             | 2             | 3             | 3              | 3             |
|  | No. of Operational Units                 | 1             | 2             | 2              | 2             |
|  | EBRT (sec)                               | 3.00          | 3.00          | 3.00           | 3.00          |
| <b>Total Permitted Flow (cfm)</b>        |  | <b>23,000</b> | <b>37,000</b> | <b>100,000</b> | <b>60,000</b> |


# Average Removal of H<sub>2</sub>S by Biotrickling Filters



# Average Removal of VOCs by Biotrickling Filters and Activated Carbon



# Average Removal of Odor by Biotrickling Filters and Activated Carbon




# JWPCP Odor Control Areas





# **Biofilters**


# Typical Biofilter Schematic




# Finished Cargo Container Modular Biofilters



# Average Inlet Odor Concentration and Percent Removal of Odors



# Inlet and Outlet GC-MS Chromatogram Plots from Modular Biofilter With Wood Media



# **JWPCP Biosolids Handling Odor Control Project**

- **Reduce odors associated with conveying and storage of dewatered biosolids**
- **Enclose and contain areas that generate odorous emissions**
- **Approx. 170,000 cfm of ultimate flow**

# **JWPCP Biosolids Handling Large Scale Biofilters**

**Total Area 1.5 Acres**



**South Biofilter: 0.65 Acres**



**East Biofilter: 0.85 Acres**

# **JWPCP Biosolids Handling Large Scale Biofilters**




# JWPCP Large Scale Biofilter Design Criteria

| Description                         | South Biofilter            | East Biofilter |
|-------------------------------------|----------------------------|----------------|
| System flow                         | 68,000 cfm                 | 88,000 cfm     |
| Number of cells                     | 4                          | 5              |
| Air flow capacity, each cell        | 17,000 cfm                 | 17,400 cfm     |
| Dimensions of each cell             | 60 ft x 100 ft             | 60 ft x 100 ft |
| Media depth, ft                     | 6 ft                       |                |
| Contact time with all cells on-line | 85 sec                     | 83 sec         |
| Contact time with one cell off-line | 64 sec                     | 66 sec         |
| Media                               | wood chips                 |                |
| Pressure drop across cells          | 0.5 inches per ft of media |                |

# JWPCP Biosolids Handling Large Scale Biofilters

## Air Plenum Plates





# **JWPCP Biosolids Handling Large Scale Biofilters**

## **Loading the Media**




# JWPCP Biosolids Handling Large Scale Biofilters

## Organic Sulfur Removal




# JWPCP Biosolids Handling Large Scale Biofilters

## Odor Removal



# Inland Empire Regional Composting (IERCF) Facility Biofilter



# IERCF Biofilter Construction



# Inland Empire Composting Facility

**Indoor Composting Facilities**

**Biofilter**



# **IERCF Very Large Scale Biofilter Design Criteria**

| <b>Description</b>                             | <b>Data</b>                       |
|--|-----------------------------------|
| <b>System flow</b>                             | <b>800,000 cfm</b>                |
| <b>Number of cells</b>                         | <b>12</b>                         |
| <b>Air flow capacity, each cell</b>            | <b>66,700 cfm</b>                 |
| <b>Dimensions per cell</b>                     | <b>85 ft x 135 ft</b>             |
| <b>Media depth, ft</b>                         | <b>6 ft</b>                       |
| <b>Contact time with<br/>all cells on-line</b> | <b>62 sec</b>                     |
| <b>Contact time with one cell off-line</b>     | <b>57 sec</b>                     |
| <b>Media</b>                                   | <b>wood chips</b>                 |
| <b>Pressure drop across cells</b>              | <b>0.5 inches per ft of media</b> |

# Questions?

