



Metropolitan Water Reclamation District of Greater Chicago

DEVELOPMENT OF PROCESS AND HYDRAULIC MODELS FOR THE CALUMET WRP AS PLANNING TOOLS

Daniel Sañabaj, Senior Civil Engineer MWRDGC

Steve Arant, Bikram Sabherwal and Amanda Burns, Black & Veatch





DANIEL SAŁABAJ, P.E.

Current: Senior Civil Engineer, Capital Facilities Planning, M&R, MWRDGC
(Since 2013)

Experience: Associate Civil Engineer, Plant Design Management, Engineering Dept. (2010-2013)
Assistant Structural Engineer, Civil/Structural Design, Engineering Dept. (2007-2010)

Haeger Engineering, LLC
Civil Engineer/Land Development: 2006-2007

Education: B.S. Civil Engineering (2005), Illinois Institute of Technology

Professional: Licensed Professional Engineer – Illinois
(Since 2011)





STEVE ARANT, P.E.

Current: Senior Process Engineer, Black & Veatch
(Since 2011)

Experience: Senior Process Engineer Earth Tech/AECOM
(1990 to 2011)

Education: B.S. Civil Engineering (1979), Marquette University
M.S. Civil and Environmental Engineering (1990), University of Wisconsin - Madison

Professional: Licensed Professional Engineer – Illinois (Since 2006)
Licensed Professional Engineer – Wisconsin (Since 1985)






OUTLINE

- **Reasons for modeling**
- **Project scope**
- **Hydraulic Model**
 - **Development Highlights**
 - **Model**
 - **Planning Tool**
- **Process Model**
 - **Development Highlights**
 - **Model**
 - **Planning Tool**
- **Concluding Remarks**



MODELING






PLANT MODELING - REASONS

- For better understanding and simplification of complex processes
 - Complicated and iterative equations
 - Vast number of elements and interaction between different treatment processes
- Less expensive and quicker to model than design and build
 - Whole plant modeling: \$200,000
 - Pilot testing: \$400,000
 - Engineering design Aerated Grit Facility & Primary Settling Tanks: \$10,000,000
 - Construction cost: \$230,000,000

“The Modelers”

➤ Planning Tool

- Capital planning
- Feasibility studies
- Engineering evaluations
- Predict plant performance for different flows/loads





PROJECT BACKGROUND & SCOPE

- **Hydraulic Model**
 - No previous models/software
- **Process Model (GPS-X 4.1.2)**
 - Completed in 2005
- **Recent major infrastructure developments at Calumet**
 - Aerated Grit Facilities and Primary Settling Tanks
 - Disinfection Facilities
 - Thornton Reservoir
- **Upcoming stringent nutrient limits**
 - TP 1.0 mg/L
 - TN in near future




HYDRAULIC MODEL DEVELOPMENT

➤ Software selection

- Visual Hydraulics 4.2+

➤ Data collection

- Contract drawings
- Surveying
- Operational data
- Knowledge from plant Operators

















HYDRAULIC MODEL DEVELOPMENT

Types of losses [X]

Choose a loss type

<input type="radio"/> Pipe or Conduit 	<input checked="" type="radio"/> Weir 
<input type="radio"/> Open Channel 	<input type="radio"/> Filter 
<input type="radio"/> Open Channel Transition 	<input type="radio"/> Bar Rack / Screen 
<input type="radio"/> Elevation Step or Drop 	<input type="radio"/> Flume 
<input type="radio"/> Orifice / Gate 	<input type="radio"/> Tank Launder 
<input type="radio"/> Junction / Connection 	<input type="radio"/> Special Loss 

Loss description (required)

Enter a description for the loss or device you are analyzing:

Section will be calculated upstream of:

LCR

OK Cancel

Help






HYDRAULIC MODEL DEVELOPMENT

1. Battery B New FST V-Notch Weir Example

V-notch weir - FSTB12_VNotch

General | Flows

V-notch weir diagram



Head over weir

V-notch angle

V-notch invert

V-notch weir characteristics

Angle of v-notch, degrees:

Invert elevation of v-notch:

Total number of notches:

Finished / Update Profile

Total notches calculator

Cancel Help

Total weir notches calculator

Tank Shape

Circular Tank

Rectangular Tank

Close Help


Calculate

Weir Characteristics

Weir ring diameter: ft

Weir perimeter length: ft

Invert spacing (width): in




Width





HYDRAULIC MODEL DEVELOPMENT

1. Battery B New FST V-Notch Weir Example





HYDRAULIC MODEL DEVELOPMENT

1. Gate/weir settings

- Battery E2 Influent Sluice Gates example



Orifice/baffle/gate - E2_SG3andSG4

General | Flows

Opening shape

Type of opening:

Rectangular gate

Orifice total open area

Opening width, in: 96

Gate height, in: 36

Invert of opening(s): -3.75

Total number of openings: 1

Diagram

Gate opening height


Finished / Update Profile

Cancel Help



HYDRAULIC MODEL DEVELOPMENT

1. Model constructed from downstream to upstream





FIELD SURVEY SUMMARY

1. Recon Visit: May 12, 2016

- Established over 100 Temporary Benchmarks around WRP
- Error in loops ranged from -0.01 ft to +0.03 ft

2. Calibration Data Collection Survey: May 19, 2016

- Flow = 206 mgd
- Gathered WSE data, operational data


3. Validation Data Collection Survey: May 26, 2016

- Maintained flow = 286 mgd
- Gathered WSE data, operational data





Example Field Survey Plan: Primary Settling Tanks (PSTs), Primary Effluent Diversion Structures, and conduit along Former Preliminary Settling Tanks






HYDRAULIC MODEL CALIBRATION

1. Calibration Goals:

- Accurately simulate flow splits
- Match measured WSEs from Field Survey

2. Calibration Variables:

- Roughness Coefficients (Manning's n , HW)
- Adjustable weir heights
- Adjustable gate openings
- Butterfly valve C_v values
- Facilities on/off line





HYDRAULIC MODEL CALIBRATION RESULTS


1. Calibrate flow splits based on downstream hydraulic losses and equalized head

BATTERY	SIMULATED FLOW (MGD)	OBSERVED FLOW (MGD)	DIFFERENCE (%)
Battery A	40.1	38.7	3.7%
Battery B	42.5	41.5	2.4%
Battery C	37.4	40.4	-7.3%
Battery E1	39.9	39.9	0.0%
Battery E2	46.0	45.5	1.1%
TOTAL	206.0	206.0	





HYDRAULIC MODEL CALIBRATION RESULTS





CALIBRATION/VALIDATION

- **Excellent calibration within 0.12 ft at all points except clarifier launders and Chlorine contact tank effluent chamber**
 - Clarifier launders difficult to survey and had algae buildup
 - High turbulence at CCT effluent chamber
- **Validation**
 - >75% of calibration points are within ± 0.1 ft of the measured value





FULL PLANT MODEL VS CRITICAL PATH MODEL

• Full Model

- Includes 1,018 model components
- Includes 85 flow split elements
- Use for Battery-specific analyses
- Use in conjunction with Critical Path Model


• Critical Path Model

- Includes 237 model components
- Includes 7 flow split elements
- Use for whole plant analyses
- Model calibration
- Determining operational controls/settings



MODEL CONFIGURATION – FULL PLANT MODEL VS CRITICAL PATH MODEL

Battery E1



- Critical Path has greater utility for full plant modeling – full plant model to be used for particular elements/basins






HYDRAULIC MODEL AS PLANNING TOOL

➤ Plant upgrades/expansion – Capital Planning

- ❖ Adding tanks for more treatment volume
- ❖ Convert chlorine disinfection to UV
- ❖ Filters for meeting lower nutrient limits
 - ❖ Lift station possibility




➤ Feasibility studies/evaluations

- ❖ Process model impacts

➤ Optimize operational scenarios

- ❖ High flow/low flow
- ❖ Taking infrastructure out of service


Hydraulic Profile - Critical Path Model



PROCESS MODEL




HAPPY ENGINEERS WEEK!






HAPPY ENGINEERS WEEK!



Two engineers
walk into a bar...

The machinist ducked!






PROCESS MODEL DEVELOPMENT

Process Model Basis

- Steady state model suitable for planning
- Use of IWA's "Good Modeling Practice Unified Protocol" for developing process model
- Set goals for model calibration
 - +/- 10% for MLSS, WAS, PS
 - +/- 15% for DS, biogas
- Model limitations based on extent and quality of data





PROCESS MODEL

1. Simple growth/decay matrix

Table 1. Process kinetics and stoichiometry for heterotrophic bacterial growth in an aerobic environment

		Continuity			
Component →	i	1	2	3	Process Rate, ρ_j [ML ⁻³ T ⁻¹]
		X_B	S_S	S_O	
j Process ↓					
1 Growth		1	$-\frac{1}{Y}$	$-\frac{1-Y}{Y}$	$\frac{\hat{\mu} S_S}{K_S + S_S} X_B$
2 Decay		-1		-1	$b X_B$
Observed Conversion Rates ML ⁻³ T ⁻¹		$r_i = \sum_j r_{ij} = \sum_j v_{ij} \rho_j$			Kinetic Parameters: Maximum specific growth rate: $\hat{\mu}$ Half-velocity constant: K_S Specific decay rate: b
Stoichiometric Parameters: True growth yield: Y		Biomass [M(COD) L ⁻³]	Substrate [M(COD) L ⁻³]	Oxygen (negative COD) [M(-COD) L ⁻³]	





PROCESS MODEL


		COMPONENT →	i	1	2	3	RATE EQUATION, ρ_i									
		Gujer matrix	BioWin nomenclature	Z _{BH}	S _{BSC}	S _{BSP}	47	48	49	50	51	NOTE: MIN functions are not the default in BioWin, default method is multiplication of Monod terms. Using MINs can lead to different process predictions				
			IWA nomenclature	X _{OHO}	S _S	S _{PROP}	S _{UD1}	S _{UD2}	X _{UD1}	X _{UD2}	S _{UD3}					
2.2	3.0		Short form (subscript)	OHO	S	PR	UD1	UD2	UD3	UD4	H ₂ O					
j	j	PROCESS ↓	UNITS	mgCOD/L	mgCOD/L	mgCOD/L	mg/L	mg/L	mg/L	mg/L	mgH ₂ O/L					
1	1	Aerobic growth of heterotrophs on complex substrate	mgCOD/L/d	1	$-\frac{1}{Y_{HET,DS}}$						column not finished	$\mu_{ZBH} * Z_{BH} * \text{MIN}(MS_{Sbc}; ME_{DO,Het}; MN_{NH3}; MN_{PO4}; MN_{CAT}; MN_{AN}) * I_{pH,ZBH}$				
2	2	Anoxic growth of heterotrophs on complex substrate using NO ₃	mgCOD/L/d	1	$-\frac{1}{Y_{HET,NO3,S}}$							$\mu_{ZBH} * \eta_{ANOX,ZBH} * Z_{BH} * 1.14/2.86 * \text{MIN}(MR_{SBC,SBSA}; MR_{SBC,SBSP}; MR_{NO3,NO2}; MS_{Sbc}; IE_{SDN,Het}; ME_{NO2}; MN_{NH3}; MN_{PO4}; MN_{CAT}; MN_{AN}) * I_{pH,ZBH}$				
new	3	Anoxic growth of heterotrophs on complex substrate using NO ₂	mgCOD/L/d	1	$-\frac{1}{Y_{HET,NO2,S}}$							$\mu_{ZBH} * \eta_{ANOX,ZBH} * Z_{BH} * 1.71/2.86 * \text{MIN}(MR_{SBC,SBSA}; MR_{SBC,SBSP}; MS_{Sbc}; IE_{SDN,Het}; ME_{NO2}; MN_{NH3}; MN_{PO4}; MN_{CAT}; MN_{AN}) * I_{pH,ZBH}$				
5	4	Aerobic growth of heterotrophs on propionate	mgCOD/L/d	1	$-\frac{1}{Y_{HET,OP}}$							$\mu_{ZBH} * Z_{BH} * \text{MIN}(MS_{Sbp}; ME_{DO,Het}; MN_{NH3}; MN_{PO4}; MN_{CAT}; MN_{AN}) * I_{pH,ZBH}$				
6	5	Anoxic growth of heterotrophs on propionate using NO ₃	mgCOD/L/d	1	$-\frac{1}{Y_{HET,NO3,PR}}$							$\mu_{ZBH} * \eta_{ANOX,ZBH} * Z_{BH} * 1.14/2.86 * \text{MIN}(MR_{SBC,SBSA}; MR_{NO3,NO2}; MS_{Sbp}; IE_{SDN,Het}; ME_{NO2}; MN_{NH3}; MN_{PO4}; MN_{CAT}; MN_{AN}) * I_{pH,ZBH}$				
new	6	Anoxic growth of heterotrophs on propionate using NO ₂	mgCOD/L/d	1	$-\frac{1}{Y_{HET,NO2,PR}}$							$\mu_{ZBH} * \eta_{ANOX,ZBH} * Z_{BH} * 1.71/2.86 * \text{MIN}(MR_{SBC,SBSA}; MS_{Sbp}; IE_{SDN,Het}; ME_{NO2}; MN_{NH3}; MN_{PO4}; MN_{CAT}; MN_{AN}) * I_{pH,ZBH}$				
9	7	Aerobic growth of heterotrophs on acetate	mgCOD/L/d	1								$\mu_{ZBH} * Z_{BH} * \text{MIN}(MS_{Sba}; ME_{DO,Het}; MN_{NH3}; MN_{PO4}; MN_{CAT}; MN_{AN}) * I_{pH,ZBH}$				
10	8	Anoxic growth of heterotrophs on acetate using NO ₃	mgCOD/L/d	1								$\mu_{ZBH} * \eta_{ANOX,ZBH} * Z_{BH} * 1.14/2.86 * \text{MIN}(MR_{NO3,NO2}; MS_{Sba}; IE_{SDN,Het}; ME_{NO2}; MN_{NH3}; MN_{PO4}; MN_{CAT}; MN_{AN}) * I_{pH,ZBH}$				
new	9	Anoxic growth of heterotrophs on acetate using NO ₂	mgCOD/L/d	1								$\mu_{ZBH} * \eta_{ANOX,ZBH} * Z_{BH} * 1.71/2.86 * \text{MIN}(MS_{Sba}; IE_{SDN,Het}; ME_{NO2}; MN_{NH3}; MN_{PO4}; MN_{CAT}; MN_{AN}) * I_{pH,ZBH}$				
13	10	Aerobic growth of heterotrophs on methanol	mgCOD/L/d	1								$\mu_{ZBH} * Z_{BH} * \text{MIN}(MS_{Smeto,AER}; ME_{DO,Het}; MN_{NH3}; MN_{PO4}; MN_{CAT}; MN_{AN}) * I_{pH,ZBH}$				
15	11	Decay of heterotrophs	mgCOD/L/d	-1								$(b_{ZBH} * ME_{DO,Het} + b_{ZBH,ANOXANA} * IE_{DO,Het}) * Z_{BH}$				
21	12	Anoxic growth of methanol utilizers using NO ₃	mgCOD/L/d									$\mu_{ZBHMETHANOX} * Z_{METH} * 1.14/2.86 * \text{MIN}(MR_{NO3,NO2}; MS_{Smeto,ANOX}; IE_{DO,Het}; ME_{NO2}; MN_{NH3}; MN_{PO4}; MN_{CAT}; MN_{AN}) * I_{pH,ZBHMETH}$				
22	13	Anoxic growth of methanol utilizers using NO ₂	mgCOD/L/d									$\mu_{ZBHMETHANOX} * Z_{METH} * 1.71/2.86 * \text{MIN}(MS_{Smeto,ANOX}; IE_{DO,Het}; ME_{NO2}; MN_{NH3}; MN_{PO4}; MN_{CAT}; MN_{AN}) * I_{pH,ZBHMETH}$				
23	14	Decay of anoxic methanol utilizers	mgCOD/L/d									$(b_{ZBHMETH} * ME_{DO,Het} + b_{ZBHMETHANOXANA} * IE_{DO,Het}) * Z_{METH}$				
26	15	Aerobic growth of polyP organisms on S _{PHB} with NH ₃	mgCOD/L/d									$\mu_{ZBP} * Z_{BP} * \text{MIN}(MR_{Sphb}; ME_{DO,Het}; ME_{PO4}; MN_{NH3}; MN_{Mg}; MN_{CAT}; MN_{Ca}; MN_{AN}) * I_{pH,ZBP}$				
28	16	Aerobic growth of polyP organisms on S _{PHB} with NH ₃ if PO ₄ -P limited	mgCOD/L/d									$\mu_{PLIM} * Z_{BP} * \text{MIN}(MR_{Sphb}; ME_{DO,Het}; IE_{PO4}; MN_{NH3}; MN_{CAT}; MN_{AN}) * I_{pH,ZBP}$				
		Anoxic growth of polyP organisms on														





PROCESS MODEL CALIBRATION

1. Model parameters adjusted to reach agreement between simulated and measured values






COD FRACTIONATION = KEY TO EBPR

1. Influent Parameters specific to Calumet WRP – Default Kinetic Parameters.

Readily biodegradable carbon (rbCOD)

Volatile fatty acids (VFA)



Fus - Non-biodegradable soluble
 Fbs - Rapidly degradable soluble fraction
 Fsd - Slowly degradable fraction

Fac - Fraction of Fbs that is SCVFA
 Fxsd - Fraction of Fsd that is particulate
 Fup - Non-biodegradable particulate fraction



INFLUENT PARAMETERS VERSUS DEFAULT VALUES

1. Influent parameters specific to Calumet WRP



FRACTION	DESCRIPTION	GPS-X DEFAULT	VALUE USED JULY 2015	VALUE USED MAY 2015	NOTES
frsi	soluble inert fraction of total COD	0.05	0.09	0.09	Estimated from Special Sampling
frss	readily biodegradable fraction of total COD	0.20	0.13	0.13	Estimated from Special Sampling
frxi	particulate inert fraction of total COD	0.13	0.24	0.23	Changed to best fit historical MLSS and WAS quantities
frscol	colloidal fraction of slowly biodegradable COD	0.15	0.23	0.23	Estimated from Special Sampling
XCOD/VSS particulate substrate	Ratio of particulate COD to volatile suspended solids	1.8	2.2	2.2	Changed to best fit historical MLSS and WAS quantities
XCOD/VSS inert particulate	Ratio of particulate COD to volatile suspended solids	1.8	1.2	1.0	Changed to best fit historical MLSS and WAS quantities through iterative process.





CALUMET WRP - 5 BATTERIES

1. Calibration – recycles included in influent flow





PROCESS MODEL CALIBRATION

1. Good correlation with liquid flow streams (influent, PE, effluent)
2. Marginal to poor correlation with solids flow streams (primary sludge, WAS, Thickened sludge, digested sludge)


PARAMETER	PLANT DATA	GPS-X	% ERROR	NOTES
MLSS, mg/L (Battery A)	2,008	1,970	2%	
WAS, ppd (Battery A)	20,200 Y = 0.83	13,600 Y = 0.55	33%	Confirm flowmeters are calibrated and sample is representative
Feed to Gravity Conc., ppd	379,000	207,000	45%	Discrepancy in primary sludge value.
Digester Feed, ppd	157,000	203,000	-29%	Confirm flowmeters are calibrated and sampling is representative
Digested Solids, ppd	122000	142,,000	-16%	

➤ Solids balance issues not unusual





PROCESS MODEL AS PLANNING TOOL



Base Case:

Full plant EBPR

Using pilot test results

Optimizing EBPR

Optimizing RAS flow & DO

Installing baffles

Carbon Addition

P Recovery

- Digested Sludge
- Centrate
- WASSTRIP

Chemical P

Nitrogen Removal

Thornton Impacts



CWRP WASTEWATER FLOWS AND LOADINGS

CONSTITUENT	AVERAGE 2015 (JULY)	SUSTAINED PEAK ⁽¹⁾
Flow	221 mgd	420 mgd
BOD	177,000 lb/d	197,000 lb/d
TSS	221,000 lb/d	245,000 lb/d
TP	9,200 lb/d	8,100 lb/d
TKN	35,400 lb/d	38,500 lb/d

Notes:

- 1. Sustained Peak occurred during March 2014 (5-day peak flow).
144 MGD (of 420 MGD) was pumped from the TARP.**

- Recycles added in full-scale model, 10°C Temp**







BASE CASE – NO CARBON ADDITION

Parameter	Value
% Basins Un aerated (Volume)	33%
Solids Handling Operations	Gravity Conc, Centrifuge, Anaerobic Digester
RAS Flow	100% influent
DO in Aeration	3.8 mg/L

PARAMETER	EFFLUENT CONCENTRATION
BOD	4.1 mg/L
TSS	4.8 mg/L
Ammonia	0.2 mg/L
NOx	6.3 mg/L
Total Nitrogen	8.7 mg/L
Ortho-P	2.4 mg/L
Total Phosphorus	2.9 mg/L
MLSS Battery A	2,220 mg/L







RAS FLOW AND DO OPTIMIZATION

BASE CASE	
NOx	6.3 mg/L
Total Nitrogen	8.7 mg/L
Ortho-P	2.4 mg/L
Total Phosphorus	2.9 mg/L
MLSS Battery A	2,220 mg/L


PARAMETER	EFFLUENT CONCENTRATION
BOD	4.3 mg/L
TSS	4.9 mg/L
Ammonia	0.2 mg/L
NOx	7.3 mg/L ↑
Total Nitrogen	9.7 mg/L ↑
Ortho-P	1.6 mg/L ↓
Total Phosphorus	2.2 mg/L ↓
MLSS Battery A	2,400 mg/L ↑





CARBON ADDITION W/ BAFFLES FOR CONTROL

BASE CASE	
NOx	6.3 mg/L
Total Nitrogen	8.7 mg/L
Ortho-P	2.4 mg/L
Total Phosphorus	2.9 mg/L
MLSS Battery A	2,220 mg/L
PARAMETER	EFFLUENT CONCENTRATION
BOD	3.7 mg/L
TSS	5.5 mg/L
Ammonia	0.2 mg/L
NOx	4.6 mg/L ↓
Total Nitrogen	7.2 mg/L ↓
Ortho-P	0.2 mg/L ↓
Total Phosphorus	0.8 mg/L ↓
MLSS Battery A	3,200 mg/L ↑
Supplemental Carbon	232,000 lb COD/day ↑






CARBON ADDITION W/ DO OPTIMIZATION

EBPR COMPARISON W/ BAFFLE & CARBON ONLY

NOx	4.6 mg/L
Total Nitrogen	7.2 mg/L
MLSS Battery A	3,200 mg/L
Supplemental Carbon	232,000 lb COD/day
PARAMETER	EFFLUENT CONCENTRATION
BOD	3.7 mg/L
TSS	5.4 mg/L
Ammonia	0.2 mg/L
NOx	3.9 mg/L ↓
Total Nitrogen	6.4 mg/L ↓
Ortho-P	0.3 mg/L
Total Phosphorus	0.9 mg/L
MLSS Battery A	3,200 mg/L
Supplemental Carbon	210,000 lb COD/day ↓







CARBON ADDITION W/ RAS OPTIMIZATION

EBPR COMPARISON W/ BAFFLE, CARBON & DO OPTIMIZATION


NOx	3.9 mg/L
Total Nitrogen	6.4 mg/L
MLSS Battery A	3,200 mg/L
Supplemental Carbon	210,000 lb COD/day

PARAMETER	EFFLUENT CONCENTRATION
BOD	3.5 mg/L
TSS	5.6 mg/L
Ammonia	0.2 mg/L
NOx	5.3 mg/L ↑
Total Nitrogen	7.8 mg/L ↑
Ortho-P	0.3 mg/L
Total Phosphorus	0.9 mg/L
MLSS Battery A	3,100 mg/L ↓
Supplemental Carbon	193,000 lb COD/day ↓







PHOSPHORUS RECOVERY



Phosphorus Recovery from Digested Sludge



Phosphorus Recovery from Centrate



WASSTRIP Process





CENTRATE P-RECOVERY

EBPR COMPARISON W/ BAFFLE, CARBON & DO OPTIMIZATION

NOx	3.9 mg/L
Total Nitrogen	6.4 mg/L
MLSS Battery A	3,200 mg/L
Supplemental Carbon	210,000 lb COD/day

PARAMETER	EFFLUENT CONCENTRATION	
BOD	3.7 mg/L	
TSS	4.9 mg/L	
Ammonia	0.2 mg/L	
NOx	4.6 mg/L	↑
Total Nitrogen	6.9 mg/L	↑
Ortho-P	0.2 mg/L	
Total Phosphorus	0.8 mg/L	
MLSS Battery A	2,300 mg/L	↓
Supplemental Carbon	99,200 lb COD/day (50%)	↓
Magnesium	2,400 lb/day	↑



CHEMICAL P-REMOVAL (BATT. A, B & C)

EBPR COMPARISON W/ BAFFLE, CARBON & DO OPTIMIZATION

NOx	3.9 mg/L
Total Nitrogen	6.4 mg/L
MLSS Battery A	3,200 mg/L
Supplemental Carbon	210,000 lb COD/day

PARAMETER	EFFLUENT CONCENTRATION	
BOD	3.0 mg/L	
TSS	4.9 mg/L	
Ammonia	0.2 mg/L	
NOx	8.3 mg/L	↑
Total Nitrogen	10.6 mg/L	↑
Ortho-P	0.3 mg/L	
Total Phosphorus	0.8 mg/L	
MLSS Battery A/E1	2,300 mg/L / 2,900 mg/L	↓
Supplemental Carbon E1 & E2	49,000 lb COD/day	↓
Ferric Chloride	17,600 lb/day	↑



NITROGEN REMOVAL (6.0 MG/L)

EBPR COMPARISON W/ BAFFLE, CARBON & DO OPTIMIZATION

NOx	3.9 mg/L
Total Nitrogen	6.4 mg/L
MLSS Battery A	3,200 mg/L
Supplemental Carbon	210,000 lb COD/day

PARAMETER	EFFLUENT CONCENTRATION
BOD	4.3 mg/L
TSS	5.7 mg/L
Ammonia	0.3 mg/L
NOx	2.0 mg/L ↓
Total Nitrogen	4.7 mg/L ↓
Ortho-P	0.2 mg/L
Total Phosphorus	0.9 mg/L
MLSS Battery A	3,700 mg/L ↑
Supplemental Carbon	228,000 lb COD/day ↑





THORNTON PUMP-BACK (BASE CASE W/ EBPR)

Parameter	Value
% Basins Unaerated (Volume)	25%
Solids Handling Operations	Gravity Conc, Centrifuge, Anaerobic Digester
RAS Flow	100% influent
DO in Aeration	2.0 mg/L

PARAMETER	EFFLUENT CONCENTRATION
BOD	4.7 mg/L
TSS	7.8 mg/L
Ammonia	0.2 mg/L
NOx	4.3 mg/L
Total Nitrogen	6.5 mg/L
Ortho-P	1.1 mg/L
Total Phosphorus	1.4 mg/L
MLSS Battery A	1,500 mg/L





THORNTON PUMP-BACK W/ EBPR & CARBON ADDITION

Parameter	Value
% Basins Unaerated (Volume)	25%
Solids Handling Operations	Gravity Conc, Centrifuge, Anaerobic Digester
RAS Flow	100% influent
DO in Aeration	2.0 mg/L

PARAMETER	EFFLUENT CONCENTRATION	
BOD	5.5 mg/L	
TSS	8.0 mg/L	
Ammonia	0.3 mg/L	
NOx	3.5 mg/L	↓
Total Nitrogen	5.7 mg/L	↓
Ortho-P	0.1 mg/L	↓
Total Phosphorus	0.8 mg/L	↓
MLSS Battery A	2,100 mg/L	↑
Supplemental Carbon	48,000 lb COD/day	↑





SUMMARY

PROCESS MODEL RUN	EFFLUENT ORTHO-P	EFFLUENT TOTAL P	EFFLUENT TOTAL NITROGEN	SUPPLEMENTAL CARBON	BATTERY A MLSS
Base Case	2.4 mg/L	2.9 mg/L	8.7 mg/L	0 lbCOD/d	2,220 mg/L
Install Baffling and Add Supplemental Carbon	0.2 mg/L	0.8 mg/L	7.2 mg/L	232,000 lbCOD/d	3,200 mg/L
Optimize DO, Install Baffling and Add Supplemental Carbon	0.3 mg/L	0.9 mg/L	6.4 mg/L	210,000 lbCOD/d	3,200 mg/L
Optimize RAS Flow and DO, Install Baffling and Add Supplemental Carbon	0.3 mg/L	0.9 mg/L	7.8 mg/L	193,000 lbCOD/d	3,100 mg/L
Optimized EBPR with Phosphorus Recovery from Centrate	0.2 mg/L	0.8 mg/L	6.9 mg/L	99,200 lbCOD/d	2,300 mg/L
Chemical Phosphorus Removal in Batteries A, B and C with Optimized EBPR in Batteries E1 and E2	0.3 mg/L	0.8 mg/L	10.6 mg/L	49,000 lbCOD/d	2,300 mg/L
Process Modeling of Additional Scenarios					
Nitrogen Removal to 6 mg/L	0.2 mg/L	0.9 mg/L	4.7 mg/L	228,000 lbCOD/d	3,700 mg/L
TCR Pump back Existing Plant	1.1 mg/L	1.4 mg/L	6.5 mg/L	0 lbCOD/d	1,500 mg/L
TCR Pump Back with Optimized EBPR without Phosphorus Recovery	0.1 mg/L	0.8 mg/L	5.7 mg/L	48,000 lbCOD/d	2,100 mg/L
TCR Pump Back with Optimized EBPR with Phosphorus Recovery	0.5 mg/L	0.9 mg/L	6.0 mg/L	0 lbCOD/d	1,800 mg/L



CWRP MODELING CONCLUSIONS

- Calibrated GPS-X model used to assess various nutrient removal upgrades/operational scenarios
 - Need jar testing for more accurate wastewater characteristics analysis and determine chemical dosing
- Useful for initial comparison of alternatives (planning, feasibility studies)
 - Design (sizing) of facilities not optimized
- Design of selected alternative requires further process modeling
 - Evaluate particular reactor sizes and multiple loading scenarios
 - Evaluate different process configurations, e.g., PS and RAS fermentation
- Investigate cost benefit in lowering DO in aeration tanks
- Investigate cost benefit in lowering RAS flow to 50%
- Removing P from side-streams/recycles has the most significant impact on lowering amount of carbon addition.



CONCLUDING REMARKS





CONCLUDING REMARKS

- Process model utilized for 1.0mg/L Total Phosphorus limit scenarios
- IEPA will soon issue new modified permits for CWRP, SWRP & OWRP
 - More stringent Total Phosphorus limits
 - ❖ 0.5 mg/L annual geometric mean
 - Require feasibility studies
 - Require modeling

We have the models!





ACKNOWLEDGEMENTS

M&R

- Judy Moran-Andrews
 - Cindy Qin
 - Joe Kozak
 - Victor Olchowka
 - Jonathan Grabowy
 - William An
 - M&R Lab Personnel
- ## Engineering
- Junli Bai
 - Glenn Rohloff



The Modelers (B&V)

- Amanda Burns
- Bikram Sabherval
- Steve Arant

Supporting Subs

- MPR Engineering
- McBride Engineering

Plant Operators:

- Sherry Kamenjarin
- Don Rohe
- Al Nichols

CWRP M&O Management

- Brian Perkovich
- Pat Connolly
- Reed Dring







Metropolitan Water Reclamation District of Greater Chicago

DEVELOPMENT OF PROCESS AND HYDRAULIC MODELS FOR THE CALUMET WRP AS PLANNING TOOLS


DANIEL SAŁABAJ, SENIOR CIVIL ENGINEER MWRDGC

STEVE ARANT, BIKRAM SABHERWAL AND AMANDA BURNS, BLACK & VEATCH





SIDESTREAM RAS FERMENTATION





PROCESS MODEL CALIBRATION TYPICAL RATIOS

1. Kinetic parameters set to default

Influent Parameter	Units	Mean	Std%	Median	Min	Max	Calumet WRP
N_T/COD_T	gN/g COD	0.09	0.21	0.09	0.05	0.20	0.09
NH_4/N_{TKN}	gN/g N	0.68	0.10	0.7	0.41	0.93	0.63
P_T/COD_T	gP/g COD	0.016	0.22	0.015	0.01	0.077	0.023
PO_4/P_T	gP/g P	0.60	0.18	0.6	0.3	0.8	0.8
COD_T/BOD_5	gCOD/gBOD	2.00	0.13	2.00	1.24	3.7	1.7
COD_S/COD_T	gCOD/gCOD	0.36	0.23	0.39	0.2	0.6	0.59
TSS/COD_T	gTSS/g COD	0.51	0.16	0.5	0.35	1.19	0.58
COD_x/VSS	gCOD/gVSS	1.73	0.12	1.7	1.3	2.2	1.5
VSS/TSS	gSS/gSS	0.77	0.10	0.8	0.55	0.9	0.75
BOD_5/BOD_{ULT}	gBOD/gBOD	0.66	0.15	0.66	0.45	0.85	0.72

