

## CAL SMA LAGOON STORAGE - MARCH 31, 2012

Lagoon	Total Capacity		Empty Lagoon Depth @ DOB (feet)	Avg. Storage per foot (mil Gal)	Present Storage Depth @ DOB (feet)	Storage Depth Remaining @ DOB (feet)	Used Storage Volume* (mil Gal)	Storage Volume Remaining (mil Gal)	Present Lagoon Input Dry Tons	
	(Cu. Yd)	(mil Gal)								
L o w  S o l i d s	1	105,000	21.3	16.7	1.275	11.20	5.5	14.3	7.0	5,010
	2	110,000	22.3	17.0	1.312	12.40	4.6	16.3	6.0	5,575
	3	101,000	20.3	18.3	1.109	0.00	18.3	0.0	20.3	0
	4	101,000	20.5	18.5	1.108	0.00	18.5	0.0	20.5	0
	5	120,000	24.2	15.3	1.582	0.00	15.3	0.0	24.2	0
	6	138,000	27.8	16.8	1.655	11.00	5.8	18.2	9.6	5,668
	7	183,000	37.0	17.3	2.139	12.00	5.3	25.7	11.3	9,682
<b>8</b>	<b>Out of Service</b>									
L a g o o n s	14	133,000	26.8	19.0	1.411	4.80	14.2	6.8	20.0	1,512
	15	121,000	24.5	19.8	1.237	0.00	19.8	0.0	24.5	0
	17	204,000	41.3	19.3	2.140	7.40	11.9	15.8	25.5	5,297
	18	210,000	42.4	19.9	2.131	8.30	11.6	17.7	24.7	8,309
	19	199,000	40.2	19.9	2.020	9.60	10.3	19.4	20.8	5,958
Total	1,726,000	349					134.1	214	47,011	

\* Used storage volume for CALSMA lagoons is based on the depth measurement at the DOB, Used storage volume=Depth remaining\*Avg. storage per foot.

Approximate number of days for emergency low-solids capacity @ 3%TS: 294 days  
 Approximate number of days for emergency low-solids capacity @ 6%TS: 588 days  
 Approximate number of days for emergency low-solids capacity @ 9%TS: 882 days

Average daily digester discharge 2006 to 2011 = 0.73mgd