

LASMA LAGOON STORAGE - JANUARY 31, 2012

Lagoon Location S L o i o n w d s s	Lagoon	Total Capacity		Empty Lagoon Depth @ DOB	Avg. Storage per foot	Present Storage Depth @ DOB	Storage Depth Remaining @ DOB	Used Storage Volume*	Storage Volume Remaining	Present Lagoon Input
		(Cu. Yd)	(mil Gal)	(feet)	(mil Gal)	(feet)	(feet)	(mil Gal)	(mil Gal)	Dry Tons
S L o i o n w d s s	23	250,000	50.5	21.70	2.33	8.80	12.90	20.5	30.0	17,474
	24	249,120	50.3	21.60	2.33	15.90	5.70	37.0	13.3	18,654
	25	243,840	49.2	16.90	2.91	5.80	11.10	16.9	32.3	3,863
	26	360,000	72.7	23.50	3.09	0.00	23.50	0.0	72.7	0
C a k e o n s	27	360,000	72.7	25.05	2.90			32.7	40.0	31,385
	28	360,000	72.7	24.00	3.03			0.4	72.3	394
	29	360,000	72.7	24.00	3.03			11.1	61.6	10,632
	30	360,000	72.7	21.70	3.35			16.1	56.7	15,405
	Total	2,542,960	514					134.7	379	97,807

* Used storage volume for low solids lagoons is based on the depth measurement at the DOB, Used storage volume=Depth remaining*Avg. storage per foot. The used storage volume for cake lagoons is based on the dry tons in the lagoon and assuming 23%TS for cake lagoons, Used Storage Volume=(DT/%TS)(2000lb/ton)(1gal/8.345lb).

Approximate number of days for emergency low-solids capacity @ 3%TS: 107 days

Approximate number of days for emergency low-solids capacity @ 6%TS: 214 days

Approximate number of days for emergency low-solids capacity @ 9%TS: 321 days

Average daily digester discharge = 3.54mgd