

LASMA LAGOON STORAGE - JULY, 2015

Lagoon	Total Capacity		Empty Lagoon Depth @ DOB	Avg. Storage per foot	Present Storage Depth @ DOB	Storage Depth Remaining @ DOB	Used Storage Volume*	Storage Volume Remaining	Present Lagoon Input
	(Cu. Yd)	(mil Gal)	(feet)	(mil Gal)	(feet)	(feet)	(mil Gal)	(mil Gal)	Dry Tons
Low	23	250,000	50.5	21.70	2.33	19.80	1.90	46.1	4.4
Low	24	249,120	50.3	21.60	2.33	15.40	6.20	35.9	14.4
Low	25	243,840	49.2	16.90	2.91	11.60	5.30	33.8	15.4
Low	26	360,000	72.7	23.50	3.09	18.30	5.20	56.6	16.1
Low	27	360,000	72.7	25.05	2.90	18.45	6.60	53.6	19.2
Cake	28	360,000	72.7	24.00	3.03			20.5	52.2
Low	29	360,000	72.7	24.00	3.03	0.00	24.00	0.0	72.7
Low	30	360,000	72.7	21.70	3.35	7.40	14.30	24.8	47.9
	Total	2,542,960	514					271.2	242
									107,078

* Used storage volume for low solids lagoons is based on the depth measurement at the DOB, Used storage volume=Depth remaining*Avg. storage per foot. The used storage volume for cake lagoons is based on the dry tons in the lagoon and assuming 23%TS for cake lagoons, Used Storage Volume=(DT/%TS)(2000lb/ton)(1gal/8.345lb).

Approximate number of days for emergency low-solids capacity @ 3%TS: 103 days

Approximate number of days for emergency low-solids capacity @ 6%TS: 205 days

Approximate number of days for emergency low-solids capacity @ 9%TS: 308 days

Average daily digester discharge = 2.36mgd