

LASMA Lagoon Storage - December 31, 2016

	Lagoon	Total Capacity		Empty Lagoon Depth @ DOB (feet)	Avg. Storage per foot (mil Gal)	Present Storage Depth @ DOB (feet)	Storage Depth Remaining @ DOB (feet)	Used Storage Volume* (mil Gal)	Storage Volume Remaining (mil Gal)	Present Lagoon Input Dry Tons
		(Cu. Yd)	(mil Gal)							
Low	23	250,000	50.5	21.70	2.33	15.90	5.80	37.0	13.5	20,058
Low	24	249,120	50.3	21.60	2.33	10.00	11.60	23.3	27.0	1,044
Low	25	243,840	49.2	16.90	2.91	15.40	1.50	44.9	4.4	17,469
Low	26	360,000	72.7	23.50	3.09	15.40	8.10	47.6	25.1	9,094
Low	27	360,000	72.7	25.05	2.90	20.45	4.60	59.4	13.4	12,292
Cake	28	360,000	72.7	24.00	3.03			29.2	43.5	28,014
Cake	29	360,000	72.7	24.00	3.03			0.0	72.7	787
Low	30	360,000	72.7	21.70	3.35	1.70	20.00	5.7	67.0	21,989
	Total	2,542,960	514					247.1	267	110,747

* Used storage volume for low solids lagoons is based on the depth measurement at the DOB, Used storage volume=Depth remaining*Avg. storage per foot. The used storage volume for cake lagoons is based on the dry tons in the lagoon and assuming 23%TS for cake lagoons, Used Storage Volume=(DT/%TS)(2000lb/ton)(1gal/8.345lb).

Approximate number of days for emergency low-solids capacity @ 3%TS: 113 days
 Approximate number of days for emergency low-solids capacity @ 6%TS: 226 days
 Approximate number of days for emergency low-solids capacity @ 9%TS: 339 days

2/7/2017
 TM

Average daily digester discharge = 2.36mgd

\\Eagle\Stickney\M&O\LASMA\Lagoon Group\2016\2016 LASMA Lagoon Storage