

NOTES:

- 1. STRUCTURE AND BAFFLE WALL FABRICATED USING REINFORCED PORTLAND CEMENT CONCRETE.
- 2. RESTRICTORS LESS THAN 4" IN DIAMETER PROVIDE HOOD/SNOUT OR WIRE MESH
- 3. BAFFLE WALL PERMANENTLY INSTALLED AS PRECAST OR CAST-IN-PLACE
- 4. PIPE TO STRUCTURE CONNECTIONS SHALL BE ASTM C923 IN COMBINED SEWER AREAS.
- 5. CAUTION: 1/4-INCH STEEL PLATE DIMENSIONS TO BEST FIT PROPOSED STRUCTURE.
- 6. ANCHOR EMBEDMENT SHALL BE 3-INCHES MINIMUM.
- 7. SEE STRUCTURAL PLANS FOR REINFORCEMENT DETAILS.

NOT TO SCALE

