

## CALSMA LAGOON STORAGE - APRIL 30, 2016

Lagoon	Total Capacity		Empty Lagoon Depth @ DOB (feet)	Avg. Storage per foot (mil Gal)	Present Storage Depth @ DOB (feet)	Storage Depth Remaining @ DOB (feet)	Used Storage Volume* (mil Gal)	Storage Volume Remaining (mil Gal)	Present Lagoon Input Dry Tons
	(Cu. Yd)	(mil Gal)							
1	105,000	21.3	16.7	1.275	11.03	5.7	14.1	7.2	1,505
2	110,000	22.3	17.0	1.312	0.58	16.4	0.8	21.5	855
3	101,000	20.3	18.3	1.109	13.68	4.6	15.2	5.1	5,006
4	101,000	20.5	18.5	1.108	15.21	3.3	16.9	3.6	4,559
5	120,000	24.2	15.3	1.582	0.00	15.3	0.0	24.2	0
6	138,000	27.8	16.8	1.655	3.72	13.1	6.2	21.6	4,295
7	183,000	37.0	17.3	2.139	1.88	15.4	4.0	33.0	6,100
8	250,000	50.4	16.0	3.150	13.33	2.7	42.0	8.4	13,894
14	133,000	26.8	19.0	1.411	16.08	2.9	22.7	4.1	7,470
15	121,000	24.5	19.8	1.237	0.00	19.8	0.0	24.5	0
17	204,000	41.3	19.3	2.140	15.47	3.8	33.1	8.2	4,444
18	210,000	42.4	19.9	2.131	0.82	19.1	1.7	40.7	1,212
19	199,000	40.2	19.9	2.020	6.07	13.8	12.3	27.9	8,591
Total	1,976,000	399					168.8	230	57,932

\* Used storage volume for CALSMA lagoons is based on the depth measurement at the DOB,  
Used storage volume=Depth remaining\*Avg. storage per foot.

Approximate number of days for emergency low-solids capacity @ 3%TS: 339 days  
 Approximate number of days for emergency low-solids capacity @ 6%TS: 677 days  
 Approximate number of days for emergency low-solids capacity @ 9%TS: 1016 days

Average daily digester discharge 2007 to 2014 = 0.68mgd