

CALSMA LAGOON STORAGE - NOVEMBER 30, 2016

Lagoon	Total Capacity		Empty Lagoon Depth @ DOB (feet)	Avg. Storage per foot (mil Gal)	Present Storage Depth @ DOB (feet)	Storage Depth Remaining @ DOB (feet)	Used Storage Volume* (mil Gal)	Storage Volume Remaining (mil Gal)	Present Lagoon Input Dry Tons
	(Cu. Yd)	(mil Gal)							
1	105,000	21.3	16.7	1.275	15.40	1.3	19.6	1.7	3,701
2	110,000	22.3	17.0	1.312	0.70	16.3	0.9	21.4	855
3	101,000	20.3	18.3	1.109	11.50	6.8	12.8	7.5	5,006
4	101,000	20.5	18.5	1.108	13.20	5.3	14.6	5.9	4,559
5	120,000	24.2	15.3	1.582	0.00	15.3	0.0	24.2	1,285
6	138,000	27.8	16.8	1.655	8.60	8.2	14.2	13.6	5,309
7	183,000	37.0	17.3	2.139	1.90	15.4	4.1	32.9	6,100
8	250,000	50.4	16.0	3.150	11.10	4.9	35.0	15.4	13,894
14	133,000	26.8	19.0	1.411	1.50	17.5	2.1	24.7	1,218
15	121,000	24.5	19.8	1.237	0.00	19.8	0.0	24.5	0
17	204,000	41.3	19.3	2.140	17.30	2.0	37.0	4.3	6,189
18	210,000	42.4	19.9	2.131	13.90	6.0	29.6	12.8	6,930
19	199,000	40.2	19.9	2.020	0.00	19.9	0.0	40.2	237
Total	1,976,000	399					170.0	229	55,284

* Used storage volume for CALSMA lagoons is based on the depth measurement at the DOB,
Used storage volume=Depth remaining*Avg. storage per foot.

Approximate number of days for emergency low-solids capacity @ 3%TS: 337 days
 Approximate number of days for emergency low-solids capacity @ 6%TS: 674 days
 Approximate number of days for emergency low-solids capacity @ 9%TS: 1010 days

Average daily digester discharge 2007 to 2014 = 0.68mgd