

LASMA LAGOON STORAGE - APRIL 30, 2012

Lagoon Location	Total Capacity	Empty Lagoon Depth @ DOB	Avg. Storage per foot	Present Storage Depth @ DOB	Storage Depth Remaining @ DOB	Used Storage Volume*	Storage Volume Remaining	Present Lagoon Input		
S a l o i o n s s	23	250,000	50.5	21.70	2.33	8.30	13.40	19.3	31.2	17,474
	24	249,120	50.3	21.60	2.33	12.70	8.90	29.6	20.7	18,654
	25	243,840	49.2	16.90	2.91	7.70	9.20	22.4	26.8	8,260
	26	360,000	72.7	23.50	3.09	0.00	23.50	0.0	72.7	0
C a k e n s	27	360,000	72.7	25.05	2.90			32.7	40.0	31,385
	28	360,000	72.7	24.00	3.03			0.0	72.7	0
	29	360,000	72.7	24.00	3.03			9.1	63.7	8,689
	30	360,000	72.7	21.70	3.35			0.0	72.7	0
Total	2,542,960	514				113.1	401	84,463		

* Used storage volume for low solids lagoons is based on the depth measurement at the DOB, Used storage volume=Depth remaining*Avg. storage per foot. The used storage volume for cake lagoons is based on the dry tons in the lagoon and assuming 23%TS for cake lagoons, Used Storage Volume=(DT/%TS)(2000lb/ton)(1gal/8.345lb).

Approximate number of days for emergency low-solids capacity @ 3%TS: 113 days

Approximate number of days for emergency low-solids capacity @ 6%TS: 226 days

Approximate number of days for emergency low-solids capacity @ 9%TS: 339 days

Average daily digester discharge = 3.54mgd