

LASMA LAGOON STORAGE - MAY, 2014

	Lagoon	Total Capacity		Empty Lagoon Depth @ DOB (feet)	Avg. Storage per foot (mil Gal)	Present Storage Depth @ DOB (feet)	Storage Depth Remaining @ DOB (feet)	Used Storage Volume* (mil Gal)	Storage Volume Remaining (mil Gal)	Present Lagoon Input Dry Tons
		(Cu. Yd)	(mil Gal)							
Low	23	250,000	50.5	21.70	2.33	14.40	7.30	33.5	17.0	20,015
Low	24	249,120	50.3	21.60	2.33	8.40	13.20	19.6	30.7	115
Low	25	243,840	49.2	16.90	2.91	11.70	5.20	34.1	15.2	12,814
Low	26	360,000	72.7	23.50	3.09	6.50	17.00	20.1	52.6	16,030
Low	27	360,000	72.7	25.05	2.90	11.75	13.30	34.1	38.6	9,068
Cake	28	360,000	72.7	24.00	3.03	0.00	24.00	0.8	71.9	734
Low	29	360,000	72.7	24.00	3.03	0.00	24.00	0.0	72.7	0
Low	30	360,000	72.7	21.70	3.35	18.80	2.90	63.0	9.7	27,476
	Total	2,542,960	514					205.1	308	86,252

* Used storage volume for low solids lagoons is based on the depth measurement at the DOB, Used storage volume=Depth remaining*Avg. storage per foot. The used storage volume for cake lagoons is based on the dry tons in the lagoon and assuming 23%TS for cake lagoons, Used Storage Volume=(DT/%TS)(2000lb/ton)(1gal/8.345lb).

Approximate number of days for emergency low-solids capacity @ 3%TS: 131 days

Approximate number of days for emergency low-solids capacity @ 6%TS: 261 days

Approximate number of days for emergency low-solids capacity @ 9%TS: 392 days

Average daily digester discharge = 2.36mgd