

## LASMA Lagoon Storage - September 30, 2016

	Lagoon	Total Capacity		Empty Lagoon Depth @ DOB (feet)	Avg. Storage per foot (mil Gal)	Present Storage Depth @ DOB (feet)	Storage Depth Remaining @ DOB (feet)	Used Storage Volume* (mil Gal)	Storage Volume Remaining (mil Gal)	Present Lagoon Input Dry Tons
		(Cu. Yd)	(mil Gal)							
Low	23	250,000	50.5	21.70	2.33	17.60	4.10	41.0	9.5	15,698
Low	24	249,120	50.3	21.60	2.33	0.70	20.90	1.6	48.7	1,429
Low	25	243,840	49.2	16.90	2.91	13.70	3.20	39.9	9.3	16,354
Low	26	360,000	72.7	23.50	3.09	12.40	11.10	38.4	34.3	9,094
Low	27	360,000	72.7	25.05	2.90	10.75	14.30	31.2	41.5	17,219
Cake	28	360,000	72.7	24.00	3.03			29.8	42.9	28,642
Low	29	360,000	72.7	24.00	3.03	0.00	24.00	0.0	72.7	0
Low	30	360,000	72.7	21.70	3.35	15.40	6.30	51.6	21.1	18,659
	Total	2,542,960	514					233.5	280	107,095

\* Used storage volume for low solids lagoons is based on the depth measurement at the DOB, Used storage volume=Depth remaining\*Avg. storage per foot. The used storage volume for cake lagoons is based on the dry tons in the lagoon and assuming 23%TS for cake lagoons, Used Storage Volume=(DT/%TS)(2000lb/ton)(1gal/8.345lb).

Approximate number of days for emergency low-solids capacity @ 3%TS:	119 days
Approximate number of days for emergency low-solids capacity @ 6%TS:	237 days
Approximate number of days for emergency low-solids capacity @ 9%TS:	356 days

Average daily digester discharge = 2.36mgd