

LASMA Lagoon Storage - August 30, 2017										
Lagoon	Total Capacity		Empty Lagoon Depth @ DOB	Avg. Storage per foot	Present Storage Depth @ DOB	Storage Depth Remaining @ DOB	Used Storage Volume*	Storage Volume Remaining	Present Lagoon Input	
	(Cu. Yd)	(mil Gal)	(feet)	(mil Gal)	(feet)	(feet)	(mil Gal)	(mil Gal)	Dry Tons	
Low	23	250,000	50.5	21.70	2.33	19.30	2.40	44.9	5.6	23,455
Low	24	249,120	50.3	21.60	2.33	15.90	5.70	37.0	13.3	11,941
Low	25	243,840	49.2	16.90	2.91	15.70	1.20	45.8	3.5	21,013
Low	26	360,000	72.7	23.50	3.09	1.00	22.50	3.1	69.6	-1,777
Low	27	360,000	72.7	25.05	2.90	8.35	16.70	24.2	48.5	5,088
Cake	28	360,000	72.7	24.00	3.03			30.1	42.6	28,926
Cake	29	360,000	72.7	24.00	3.03			0.0	72.7	9,414
Low	30	360,000	72.7	21.70	3.35	18.80	2.90	63.0	9.7	28,875
	Total	2,542,960	514					248.2	265	126,935

* Used storage volume for low solids lagoons is based on the depth measurement at the DOB, Used storage volume=Depth remaining*Avg. storage per foot. The used storage volume for cake lagoons is based on the dry tons in the lagoon and assuming 23%TS for cake lagoons, Used Storage Volume=(DT/%TS)(2000lb/ton)(1gal/8.345lb).

Approximate number of days for emergency low-solids capacity @ 3%TS: 112 days

Approximate number of days for emergency low-solids capacity @ 6%TS: 225 days

Approximate number of days for emergency low-solids capacity @ 9%TS: 337 days

TM 9/28/17

Average daily digester discharge = 2.36mgd