

*Protecting Our Water Environment*



*Metropolitan Water Reclamation District of Greater Chicago*

***RESEARCH AND DEVELOPMENT  
DEPARTMENT***

***REPORT NO. 01-11***

***RADIOLOGICAL MONITORING OF THE RAW SEWAGE,  
FINAL EFFLUENT, SLUDGES, AND BIOSOLIDS OF  
THE METROPOLITAN WATER RECLAMATION DISTRICT***

***OF GREATER CHICAGO***

***1999 ANNUAL REPORT***

***May 2001***

**Metropolitan Water Reclamation District of Greater Chicago**

100 East Erie Street

Chicago, IL 60611-2803

(312) 751-5600

RADIOLOGICAL MONITORING OF THE RAW SEWAGE,  
FINAL EFFLUENT, SLUDGES, AND BIOSOLIDS OF THE  
METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO  
1999 ANNUAL REPORT

By

Sheila Kawalko  
Sanitary Chemist I

Abdul Khalique  
Radiation Chemist

Richard Pietz  
Coordinator of Technical Services

Prakasam Tata  
Assistant Director of Research and Development  
Environmental Monitoring and Research Division

Richard Lanyon, Director  
Research and Development Department

May 2001

## TABLE OF CONTENTS

	<u>Page</u>
LIST OF TABLES	iii
ACKNOWLEDGMENT	vi
DISCLAIMER	vi
SUMMARY AND CONCLUSIONS	vii
INTRODUCTION	1
MATERIALS AND METHODS	4
Sample Collection	4
Raw Sewage	4
Final Effluent	4
Sewage Sludge	4
Lagooned Sludge	4
Biosolids	4
Analytical Methodology	5
Raw Sewage and Final Effluent	5
Sludge Samples	5
Gamma Radioactivity	6
Calculations	7
Lower Limit of Detection	8
RESULTS AND DISCUSSION	10
Stickney WRP	10
Calumet WRP	10
North Side WRP	14
John E. Egan WRP	18

TABLE OF CONTENTS (Continued)

	<u>Page</u>
Hanover Park WRP	18
James C. Kirie WRP	21
Lemont WRP	25
Gross Alpha and Gross Beta Radioactivity in Hanover Park WRP Lagooned Sludge	25
Gross Alpha and Gross Beta Radioactivity in District Biosolids	30
Gamma Radioactivity in District WRP Sludges and Bio- Solids	30
REFERENCES	38

## LIST OF TABLES

<u>Table No.</u>		<u>Page</u>
1	Gross Alpha Radioactivity in Stickney WRP Raw Sewage, Final Effluent, and Anaerobically Digested Sludge, and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	11
2	Gross Beta Radioactivity in Stickney WRP Raw Sewage, Final Effluent, and Anaerobically Digested Sludge, and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	12
3	Gross Alpha Radioactivity in Calumet WRP Raw Sewage, Final Effluent, and Anaerobically Digested Sludge, and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	13
4	Gross Beta Radioactivity in Calumet WRP Raw Sewage, Final Effluent, and Anaerobically Digested Sludge, and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	15
5	Gross Alpha Radioactivity in North Side WRP Raw Sewage, Final Effluent, and Waste-Activated Sludge, and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	16
6	Gross Beta Radioactivity in North Side WRP Raw Sewage, Final Effluent, and Waste-Activated Sludge, and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	17
7	Gross Alpha Radioactivity in John E. Egan WRP Raw Sewage, Final Effluent, and Anaerobically Digested Sludge, and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	19
8	Gross Beta Radioactivity in John E. Egan WRP Raw Sewage, Final Effluent, and Anaerobically Digested Sludge, and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	20

LIST OF TABLES (Continued)

<u>Table No.</u>		<u>Page</u>
9	Gross Alpha Radioactivity in Hanover Park WRP Raw Sewage, Final Effluent, and Anaerobically Digested Sludge, and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	22
10	Gross Beta Radioactivity in Hanover Park WRP Raw Sewage, Final Effluent, and Anaerobically Digested Sludge, and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	23
11	Gross Alpha Radioactivity in James C. Kirie WRP Raw Sewage, Final Effluent, and Waste-Activated Sludge, and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	24
12	Gross Beta Radioactivity in James C. Kirie WRP Raw Sewage, Final Effluent, and Waste-Activated Sludge, and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	26
13	Gross Alpha Radioactivity in Lemont WRP Raw Sewage, Final Effluent, and Waste-Activated Sludge and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	27
14	Gross Beta Radioactivity in Lemont WRP Raw Sewage, Final Effluent, and Waste-Activated Sludge and Radioactivity Removal Efficiency of the WRP on a Monthly Basis - 1999	28
15	Gross Alpha and Gross Beta Radioactivity in Hanover Park WRP Lagooned Sludge - 1999	29
16	Gross Alpha and Gross Beta Radioactivity of District Biosolids - 1999	31
17	Concentration of Gamma-Emitting Radionuclides in WRP Sludges - 1999	33
18	Concentration of Gamma-Emitting Radionuclides in Hanover Park WRP Lagooned Sludge - 1999	34

LIST OF TABLES (Continued)

<u>Table No.</u>		<u>Page</u>
19	Concentration of Gamma-Emitting Radionuclides in District Biosolids - 1999	35

#### ACKNOWLEDGMENT

Special thanks are due to Mrs. Nancy Urlacher for typing the report.

#### DISCLAIMER

Mention of proprietary equipment and chemicals in this report does not constitute endorsement by the Metropolitan Water Reclamation District of Greater Chicago.



## SUMMARY AND CONCLUSIONS

The discharge of radioactive materials into the sanitary sewer system is regulated by the Nuclear Regulatory Commission (NRC). In Illinois, hospitals, industries, research organizations, and other radioactive material license holders are allowed to dispose of radionuclides into the sanitary sewer system in accordance with 32 Illinois Administrative Code (IAC), Section 340.1030. Naturally occurring radionuclides in groundwater and stormwater runoff also enter the sanitary sewer system. There have been several reported cases of radioactive contamination in wastewater treatment plants in United States over the last 20 years (1).

This study was conducted to determine the radioactivity concentration in raw sewage, final effluent, waste-activated sludge, digester draw sludge, lagooned sludge, and biosolids at the facilities owned and operated by the Metropolitan Water Reclamation District of Greater Chicago (District). The radioactivity removal efficiency by the wastewater treatment process at all the water reclamation plants (WRPs) was calculated. Radiological monitoring was also conducted to develop baseline data on radioactivity occurring in the District's sewage sludge and biosolids.

Weekly samples of raw sewage and monthly samples of final effluent were collected from the District's seven WRPs. Sewage sludge samples were collected on a monthly basis from all

the WRPs. Lagooned sludge samples from the Hanover Park WRP East and Hanover Park WRP West lagoons were collected twice in 1999. Final air-dried biosolids samples from the Calumet WRP East, Calumet WRP West, Ridgeland Avenue Solids Management Area (RASMA), Stony Island, Harlem Avenue Solids Management Area (HASMA), Lawndale Avenue Solids Management Area (LASMA), Marathon, and Vulcan drying areas were collected monthly from May through September 1999, and were analyzed for gross alpha and gross beta radioactivity. Samples of digester draw from the WRPs and lagooned sludge from Hanover Park WRP were analyzed for gamma-emitting radionuclides. Biosolids samples from the District drying areas were also analyzed for gamma-emitting radionuclides.

The analytical data demonstrate that radioactivity in the final effluent of all the WRPs is generally lower than the corresponding raw sewage of the WRP. This indicates that the WRPs are removing radioactivity from the raw sewage. Analytical data also indicate that the radioactivity removed, 0.7 to 82.6 percent, is concentrated in the sewage sludge generated at the various WRPs.

The amount of gross alpha and gross beta radioactivity in the final effluent is less than the allowable contaminant levels in community water standards set by the United States Environmental Protection Agency (USEPA) National Primary Drinking Water Regulations, 40 CFR Part 141. The USEPA limits for gross alpha radioactivity (including radium-226, but ex-

cluding radon and uranium) are 15 pCi/L and for gross beta radioactivity are 50 pCi/L. The gross beta radioactivity in the final effluent is also less than the General Use water quality standard, 100 pCi/L, established by the Illinois Pollution Control Board (IPCB) and found at 35C IAC, Section 302.207. Hence, the discharge of the final effluent from the seven WRPs has no adverse effect on the radiological quality of the District waterways. There are no IPCB standards for gross alpha radioactivity in General Use waters.

Measurable concentrations of gross alpha and gross beta radioactivity were found in Hanover Park WRP lagooned sludge. The average gross alpha radioactivity in the lagooned sludge was 6.5 pCi/g dry weight (dw). The average gross beta radioactivity in the lagooned sludge ranged from 15.2 to 18.1 pCi/g dw.

Measurable concentrations of gross alpha and gross beta radioactivity were found in biosolids samples from all the sludge drying areas of the District. The average gross alpha radioactivity of biosolids from these areas ranged from 6.0 to 7.9 pCi/g dw. The average gross beta radioactivity of biosolids ranged from 21.5 to 28.6 pCi/g dw.

Samples of the anaerobically digested sludge draw from four WRPs (Calumet, John E. Egan [Egan], Hanover Park, and Stickney), waste-activated sludge from the Lemont WRP, lagooned sludge from the Hanover Park WRP, and biosolids samples from drying areas were further analyzed for 24 specific radio-

nuclides by gamma spectroscopy. Of these, only potassium-40, radium-226, and cesium-137 were detected in measurable quantities in these samples. Two of these radionuclides, potassium-40 and radium-226, are of natural origin. The third radionuclide, cesium-137, is a man-made radionuclide.

Average potassium-40 radioactivity in the WRP sludge samples ranged from 5.3 to 10.9 pCi/g dw, radium-226 radioactivity ranged from 2.1 to 74.6 pCi/g dw, and cesium-137 radioactivity ranged from not detectable to 0.1 pCi/g dw.

Average potassium-40 radioactivity in Hanover Park lagooned sludge samples ranged from 4.6 to 5.0 pCi/g dw, radium-226 radioactivity ranged from 4.2 to 4.4 pCi/g dw, and cesium-137 radioactivity ranged from 0.005 to 0.01 pCi/g dw.

Average potassium-40 and radium-226 radioactivity in all the biosolids samples taken from District sludge drying areas ranged from 9.3 to 12.4 pCi/g dw and 2.9 to 4.1 pCi/g dw, respectively, and the average cesium-137 radioactivity was 0.1 pCi/g dw. Currently, there are no USEPA standards for radioactivity in biosolids.

## INTRODUCTION

The District is located within the boundaries of Cook County, Illinois and serves an area of 872 square miles. The area served by the District includes the city of Chicago and 125 suburban communities with a combined population of 5.1 million people. In addition, a waste load equivalent of 4.9 million people is contributed within the District's service area by industrial and commercial sources. On the average the District treats 1,500 million gallons per day (MGD) of wastewater at its seven WRPs.

The discharge of radionuclides to the District's sewerage system is regulated by the NRC. Radioactivity in the sewerage system may come from a variety of sources including industries, hospitals, and research organizations. Naturally occurring and fallout radionuclides also enter the sewerage system from groundwater and through stormwater runoff. Radionuclides in the sanitary sewer system pass through the wastewater treatment process where some fraction of these radionuclides are removed from the wastewater and become concentrated in the sludge, or remain in solution and pass with the effluent to the receiving water. Radioactivity contained in WRP effluents and the potential radioactivity concentration in municipal sludge may be of environmental concern because of the discharge of effluents to receiving waters, and land application or landfilling of biosolids (final sludge product

destined for disposal) as fertilizer and soil conditioner.

The District monitors the quality of its raw sewage, effluents, sludges, and biosolids for possible radioactive contamination. As a part of its monitoring program, the District's Radiochemistry Laboratory routinely analyzes raw sewage, final effluent, and sludge samples from all the WRPs, and biosolids samples from drying areas for gross alpha and gross beta radioactivity. Samples of the anaerobically digested sludge from four WRPs (Calumet, Egan, Hanover Park, and Stickney), waste-activated sludge from the Lemont WRP, lagooned sludge from the Hanover Park WRP, and biosolids samples from the District's drying areas are also examined for gamma-emitting radionuclides. In 1996, the Radiochemistry Section expanded its monitoring program of District sludges in response to the increased emphasis on sludge characteristics brought about by adoption of USEPA sludge regulations (40 CFR Part 503). Although there are no standards for radioactivity in these regulations, the District expanded its database on radiological characteristics of its biosolids to be prepared to address any future revision of the regulatory limits on gamma-emitting radionuclides.

This report describes the gross alpha and gross beta radioactivity concentrations in raw sewage, final effluent, and sewage sludge from the District's seven WRPs and biosolids from the District's drying areas. The radioactivity removal efficiency of the seven WRPs is also reported. The concentra-

tions of gross alpha and gross beta radioactivity and gamma-emitting radionuclides in quarterly samples of digester draw, lagooned sludge, and biosolids samples are also reported.

## MATERIALS AND METHODS

### Sample Collection

#### RAW SEWAGE

Composite samples of raw sewage were collected on a weekly basis from the Stickney, Egan, North Side, James C. Kirie (Kirie), Hanover Park, Calumet, and Lemont WRPs. The samples were preserved with hydrochloric acid.

#### FINAL EFFLUENT

One final effluent composite sample (composited over a period of 24 hours) was collected once a month from the effluent sampler at all the WRPs. The samples were preserved with hydrochloric acid.

#### SEWAGE SLUDGE

Anaerobically digested sludge samples were collected monthly from the Stickney, Calumet, Egan, and Hanover Park WRPs. Waste-activated sludge samples were collected monthly from the Lemont, North Side, and Kirie WRPs; these WRPs do not have digesters.

#### LAGOONED SLUDGE

Lagooned sludge samples were collected quarterly from Hanover Park WRP East and West lagoons.

#### BIOSOLIDS

Final air-dried biosolids samples were collected from



various drying areas of the District. The samples analyzed for radioactivity included biosolids from the Marathon Drying Cells, LASMA Drying Cells, Vulcan Drying Cells, HASMA Drying Cells, RASMA Drying Cells, Stony Island Drying Area, Calumet WRP East Drying Area, and Calumet WRP West Drying Area.

### Analytical Methodology

#### RAW SEWAGE AND FINAL EFFLUENT

Gross alpha and gross beta radioactivity concentrations in the samples were determined using Standard Methods for the Examination of Water and Wastewater (Standard Methods 1998) procedures.

A known volume of a thoroughly mixed grab sample was transferred to a tared evaporating dish. Methyl orange indicator solution (1 to 2 drops) was added to it. Drops of nitric acid (1N) were added until the indicator color changed to pink. The sample was evaporated on a hot plate at low heat to about 5 to 10 ml. It was then transferred quantitatively to a tared stainless steel planchet and dried under an infrared lamp, followed by oven drying at 103°C to constant weight. The sample was counted for gross alpha and gross beta radioactivity on a Tennelec LB5100 Gas Proportional counter.

#### SLUDGE SAMPLES

Gross alpha and gross beta radioactivity concentrations in the samples were determined using Standard Methods proce-

dures as follows:

A thoroughly mixed sludge sample (25 to 50 g) was transferred to a tared evaporating dish. The sample was dried to constant weight at 103°C. The difference in weight over the empty dish represents the total solids. The sample was then incinerated at 550°C to constant weight. The residue in the dish represents the fixed solids. The fixed solids were ground to a fine powder, and a weighed portion of the powder (80 to 100 mg) was transferred to a tared stainless steel planchet. The residue was distributed to a uniform thickness and spread with a few drops of 0.5 percent (w/v) acrylic (Lucite) solution in acetone. It was then dried to constant weight at 103°C and counted for gross alpha and gross beta radioactivity on a Tennelec LB5100 Gas Proportional counter.

#### GAMMA RADIOACTIVITY

Gamma radioactivity in the sludge samples was determined as follows:

The sludge sample was dried on a hot plate at low heat. It was then ground and passed through a 30-mesh sieve. The sieved material was packed in a tared 3 oz. canister and weighed. The sample was analyzed by a gamma spectroscopy system equipped with a high-purity germanium detector and Gamma-Trac software analysis package from Oxford Instrument Inc. The energy and efficiency calibration of the system was verified before the sample was counted using a National Institute

of Standards and Technology (NIST) traceable standard.

### Calculations

Gross alpha and gross beta radioactivity in sludge samples were calculated as pCi/g dw using the following equation:

$$\text{Radioactivity (pCi/g)} = \frac{\text{Net CPM} \times A}{2.22 \times \text{counting efficiency} \times B \times C}$$

where:

A = wt. of fixed solids in evaporating dish, g

B = wt. of fixed solids in planchet, g

C = wt. of total solids in evaporating dish, g

2.22 = conversion factor from dpm to pCi

Gross alpha and gross beta radioactivity in the influent and effluent were calculated as pCi/L using the following equation:

$$\text{Radioactivity (pCi/L)} = \frac{\text{Net CPM}}{2.22 \times \text{counting efficiency} \times \text{sample volume}}$$

The radioactivity removal efficiency was calculated on a monthly basis using the following equation:

Radioactivity Removal Efficiency .

$$100 \times \frac{(\text{Raw Sewage Radioactivity Conc.} - \text{Final Effluent Radioactivity Conc.})}{\text{Raw Sewage Radioactivity Conc.}}$$

where:

Raw sewage radioactivity concentration is the average of concentration of alpha/beta radioactivity in four weekly raw sewage samples collected during a month.

Final effluent radioactivity concentration is the al-

pha/beta radioactivity in the monthly effluent grab sample.

Radioactivity removal efficiency could not be calculated for the samples whose gross alpha/beta radioactivity concentration was below the detection limit.

#### Lower Limit of Detection (LLD)

The LLD is the smallest quantity of sample radioactivity that will yield a net count for which there is a predetermined level of confidence that radioactivity is present. The LLD that has a 95 percent probability of being detected was calculated as follows:

$$\text{LLD (pCi/L)} = \frac{4.66 (B)^{1/2}}{2.22 \times E \times V \times T \times F}$$

where:

B = background counts

E = counting efficiency

V = sample volume in liters

T = counting time

F = gamma fraction for the isotope line (applied only to gamma spectroscopic measurements)

When the sample radioactivity was less than the LLD, the radioactivity concentration was reported as below the detection limit.

For calculation purposes, less than LLD values were considered as real numbers, i.e., <1 was considered as 1. Average gross alpha and gross beta radioactivity for raw sewage was calculated by adding radioactivity concentrations in weekly samples

and dividing the sum by the number of weekly samples collected during the month. If any value in the individual data set with the less than symbol was higher than the average value, then the average value was reported with the less than symbol. If all the values in the individual data set with the less than symbol were lower than the average value, then the average value was reported without the less than symbol.

In a set of data points with a combination of real number and LLD values, the highest real number was considered as the maximum value if the number was higher than the highest LLD value of the data set, otherwise LLD was reported as the maximum value. The lowest real number was considered as the minimum value if the number was lower than the lowest LLD value of the data set, otherwise LLD was reported as the minimum value.

The LLD is inversely proportional to the counting efficiency and varies with the nature of the sample. A sample with a higher total solids content results in a greater thickness of solids in the counting planchet. The higher solids content in the planchet leads to a lower counting efficiency and a higher detection limit. Consequently, the detection limit will vary with the solids content of the samples and the thickness of the solids in the planchet.

## RESULTS AND DISCUSSION

### Stickney WRP

In 1999, the gross alpha radioactivity levels in the raw sewage of the Stickney WRP ranged from <3.6 (below the detection limit) to 6.4 pCi/L, and in the effluent it was below the detection limit (3.0 to 5.6 pCi/L), except for the October sample which was 3.1 pCi/L (Table 1). The gross alpha radioactivity in anaerobically digested sludge ranged from 4.4 to 11.2 pCi/g dw (Table 1). The gross alpha radioactivity removal efficiency values could not be calculated because the effluent radioactivity was below the detection limits. The gross beta radioactivity levels in the raw sewage of the Stickney WRP ranged from 16.8 to 47.8 pCi/L, and in the effluent it ranged from 7.3 to 17.9 pCi/L (Table 2). The gross beta radioactivity removal efficiency of the Stickney WRP ranged from 21.5 to 82.6 percent. The gross beta radioactivity in anaerobically digested sludge ranged from 23.7 to 44.6 pCi/g dw (Table 2).

### Calumet WRP

In 1999, gross alpha radioactivity levels in the raw sewage of the Calumet WRP ranged from below the detection limit (3.7 pCi/L) to 6.1 pCi/L, and in the effluent it was below the detection limit (3.2 to 5.8 pCi/L) (Table 3). The gross alpha radioactivity in anaerobically digested sludge ranged from 4.8 to 10.4 pCi/g dw (Table 3). The gross alpha radioactivity re-

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 1

GROSS ALPHA RADIOACTIVITY IN STICKNEY WRP RAW SEWAGE,  
FINAL EFFLUENT, AND ANAEROBICALLY DIGESTED SLUDGE,  
AND RADIOACTIVITY REMOVAL EFFICIENCY OF THE WRP  
ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Alpha (pCi/L)	Effluent Gross Alpha (pCi/L)	Radioactivity Removal Eff. (%)	Digested Sludge Gross Alpha (pCi/g dw)
January	<3.6	<3.8	*	5.3
February	5.3	<3.2	*	5.9
March	5.2	<3.3	*	6.0
April	6.4	<3.4	*	5.5
May	5.9	<3.2	*	7.5
June	4.2	<3.0	*	5.4
July	4.7	<3.6	*	7.0
August	5.2	<3.1	*	6.0
September	5.2	<3.0	*	4.4
October	<4.5	3.1	*	7.4
November	<4.7	<5.6	*	11.2
December	<4.9	<4.4	*	NS

\*Values could not be calculated because the raw sewage or effluent radioactivity was below the detection limit.

< = The quantity listed is the smallest amount that could be measured at 95 percent confidence level (lower limit of detection).

NS = No Sample

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 2

GROSS BETA RADIOACTIVITY IN STICKNEY WRP RAW SEWAGE,  
 FINAL EFFLUENT, AND ANAEROBICALLY DIGESTED SLUDGE,  
 AND RADIOACTIVITY REMOVAL EFFICIENCY OF THE WRP  
 ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Beta (pCi/L)	Effluent Gross Beta (pCi/L)	Radioactivity Removal Eff. (%)	Digested Sludge Gross Beta (pCi/g dw)
January	16.8	9.7	42.3	24.4
February	30.7	13.6	55.7	28.6
March	26.4	11.2	57.6	25.5
April	25.2	8.5	66.3	25.6
May	47.8	8.3	82.6	29.9
June	32.8	7.3	77.7	28.7
July	27.0	8.8	67.4	26.8
August	30.8	11.1	64.0	24.6
September	35.8	12.5	65.1	23.7
October	22.8	17.9	21.5	24.1
November	26.2	12.9	50.8	44.6
December	24.2	11.1	54.1	NS

NS = No Sample



METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 3

GROSS ALPHA RADIOACTIVITY IN CALUMET WRP RAW SEWAGE,  
FINAL EFFLUENT, AND ANAEROBICALLY DIGESTED SLUDGE,  
AND RADIOACTIVITY REMOVAL EFFICIENCY OF THE WRP  
ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Alpha (pCi/L)	Effluent Gross Alpha (pCi/L)	Radioactivity Removal Eff. (%)	Digested Sludge Gross Alpha (pCi/g dw)
January	<3.7	<3.8	*	5.8
February	<4.1	<3.4	*	4.8
March	<4.1	<4.1	*	6.5
April	5.7	<3.5	*	6.0
May	<3.9	<3.6	*	7.0
June	<3.8	<3.3	*	7.0
July	4.9	<3.4	*	5.3
August	6.1	<3.2	*	6.1
September	4.2	<3.3	*	5.1
October	<4.3	<3.4	*	7.6
November	<5.1	<5.8	*	10.4
December	<5.6	<4.5	*	6.5

\*Values could not be calculated because the effluent radioactivity was below the detection limit.

< = The quantity listed is the smallest amount that could be measured at 95 percent confidence level (lower limit of detection).

removal efficiency value could not be calculated because the effluent radioactivity was below the detection limits.

The gross beta radioactivity levels in the raw sewage of the Calumet WRP ranged from 15.2 to 40.9 pCi/L, and in the effluent it ranged from 7.6 to 28.0 pCi/L (Table 4). The gross beta radioactivity removal efficiency of the Calumet WRP ranged from 13.2 to 72.0 percent. The gross beta radioactivity in Calumet WRP anaerobically digested sludge ranged from 17.4 to 27.7 pCi/g dw (Table 4).

#### North Side WRP

In 1999, gross alpha radioactivity level in the raw sewage of the North Side WRP ranged from below the detection limit (3.2 pCi/L) to 5.9 pCi/L. The gross alpha radioactivity in the effluent was below the detection limits (3.0 to 4.7 pCi/L), except for the February sample which was 3.9 pCi/L (Table 5). The gross alpha radioactivity in waste-activated sludge ranged from 2.8 to 5.3 pCi/g dw (Table 5). The gross alpha radioactivity removal efficiency values could not be calculated because the raw sewage or effluent radioactivity was below the detection limit.

The gross beta radioactivity levels in the raw sewage of the North Side WRP ranged from 10.9 to 29.0 pCi/L, and in the effluent it ranged from 6.8 to 19.0 pCi/L (Table 6). The gross beta radioactivity removal efficiency of the North Side WRP ranged from 1.5 to 59.6 percent (Table 6). The gross beta

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 4

GROSS BETA RADIOACTIVITY IN CALUMET WRP RAW SEWAGE,  
 FINAL EFFLUENT, AND ANAEROBICALLY DIGESTED SLUDGE,  
 AND RADIOACTIVITY REMOVAL EFFICIENCY OF THE WRP  
 ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Beta (pCi/L)	Effluent Gross Beta (pCi/L)	Radioactivity Removal Eff. (%)	Digested Sludge Gross Beta (pCi/g dw)
January	15.8	7.6	15.9	21.6
February	26.6	15.5	41.7	19.3
March	15.2	13.2	13.2	21.1
April	17.8	10.4	41.6	23.0
May	31.3	12.1	61.3	25.3
June	31.2	11.4	63.5	27.7
July	40.0	11.2	72.0	17.4
August	40.9	22.9	44.0	23.2
September	19.4	12.5	35.6	22.2
October	16.6	28.0	68.7	22.6
November	22.1	16.2	26.7	22.9
December	21.4	8.6	59.8	20.5

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 5

GROSS ALPHA RADIOACTIVITY IN NORTH SIDE WRP RAW SEWAGE, FINAL EFFLUENT, AND WASTE-ACTIVATED SLUDGE, AND RADIOACTIVITY REMOVAL EFFICIENCY OF THE WRP ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Alpha (pCi/L)	Effluent Gross Alpha (pCi/L)	Radioactivity Removal Eff. (%)	Waste- Activated Sludge Gross Alpha (pCi/g dw)
January	<3.6	<4.1	*	3.4
February	<3.2	3.9	*	2.9
March	<3.3	<3.2	*	4.3
April	5.9	<3.6	*	3.2
May	<3.6	<3.0	*	3.1
June	<3.5	<3.3	*	4.1
July	<3.9	<3.7	*	4.0
August	<3.4	<3.3	*	2.8
September	<3.8	<3.0	*	2.9
October	<4.0	<3.2	*	4.8
November	<4.3	<4.7	*	3.8
December	<4.9	<3.4	*	5.3

\*Values could not be calculated because the raw sewage or effluent radioactivity was below the detection limit.

< = The quantity listed is the smallest amount that could be measured at 95 percent confidence level (lower limit of detection).

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 6

GROSS BETA RADIOACTIVITY IN NORTH SIDE WRP RAW SEWAGE, FINAL EFFLUENT, AND WASTE-ACTIVATED SLUDGE, AND RADIOACTIVITY REMOVAL EFFICIENCY OF THE WRP ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Beta (pCi/L)	Effluent Gross Beta (pCi/L)	Radioactivity Removal Eff. (%)	Waste- Activated Sludge Gross Beta (pCi/g dw)
January	21.3	11.2	47.4	12.8
February	13.1	12.9	1.5	12.8
March	10.9	6.8	37.6	12.3
April	20.1	8.8	56.2	13.2
May	22.3	9.8	56.0	15.5
June	24.9	10.2	59.0	16.8
July	19.3	7.8	59.6	13.8
August	17.0	10.8	36.4	12.7
September	16.6	7.8	53.0	10.1
October	29.0	19.0	34.5	15.0
November	14.4	12.8	11.1	10.7
December	20.0	13.2	34.0	15.0

radioactivity in North Side WRP waste-activated sludge sample ranged from 10.1 to 16.8 pCi/g dw (Table 6).

#### John E. Egan WRP

In 1999, the gross alpha radioactivity levels in the raw sewage of the Egan WRP ranged from below the detection limits (3.5 to 4.7 pCi/L). However, it ranged from 3.6 to 4.0 pCi/L in February, March, May, and July. The gross alpha radioactivity in the effluent was below the detection limits (2.9 to 4.9 pCi/L) (Table 7). The gross alpha radioactivity in anaerobically digested sludge samples ranged from 3.5 to 7.1 pCi/g dw (Table 7). The gross alpha radioactivity removal efficiency values could not be calculated because the effluent radioactivity was below the detection limit.

The gross beta radioactivity levels in the raw sewage of the Egan WRP ranged from 14.0 to 31.2 pCi/L, and in the effluent it ranged from 7.3 to 19.2 pCi/L (Table 8). The gross beta radioactivity removal efficiency of the Egan WRP ranged from 2.0 to 76.6 percent. The gross beta radioactivity in anaerobically digested sludge ranged from 16.8 to 22.8 pCi/g dw.

#### Hanover Park WRP

In 1999, gross alpha radioactivity levels in the raw sewage of the Hanover Park WRP was below the detection limit (3.4 to 5.3 pCi/L), except for the April sample which was 4.1 pCi/L. The gross alpha radioactivity in the effluent was below

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 7

GROSS ALPHA RADIOACTIVITY IN JOHN E. EGAN WRP RAW SEWAGE,  
FINAL EFFLUENT, AND ANAEROBICALLY DIGESTED SLUDGE,  
AND RADIOACTIVITY REMOVAL EFFICIENCY OF THE WRP  
ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Alpha (pCi/L)	Effluent Gross Alpha (pCi/L)	Radioactivity Removal Eff. (%)	Digested Sludge Gross Alpha (pCi/g dw)
January	<3.5	<3.6	*	5.1
February	3.8	<2.9	*	3.5
March	3.9	<3.2	*	5.3
April	<3.9	<3.8	*	4.7
May	3.6	<3.6	*	5.1
June	<4.0	<3.2	*	5.9
July	4.0	<3.6	*	5.2
August	<3.7	<3.2	*	5.3
September	<3.5	<3.0	*	3.9
October	<4.1	<3.3	*	6.0
November	<4.7	<4.9	*	6.3
December	<4.7	<3.5	*	7.1

\*Values could not be calculated because the effluent radioactivity was below the detection limit.

< = The quantity listed is the smallest amount that could be measured at 95 percent confidence level (lower limit of detection).

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 8

GROSS BETA RADIOACTIVITY IN JOHN E. EGAN WRP RAW SEWAGE,  
 FINAL EFFLUENT, AND ANAEROBICALLY DIGESTED SLUDGE,  
 AND RADIOACTIVITY REMOVAL EFFICIENCY OF THE WRP  
 ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Beta (pCi/L)	Effluent Gross Beta (pCi/L)	Radioactivity Removal Eff. (%)	Digested Sludge Gross Beta (pCi/g dw)
January	19.6	19.2	2.0	18.7
February	14.0	14.5	3.6	18.0
March	14.6	11.5	21.2	19.3
April	17.3	11.4	34.1	20.9
May	20.3	9.9	51.2	21.9
June	31.2	7.3	76.6	22.8
July	22.6	14.3	36.7	21.3
August	27.3	11.4	58.2	22.0
September	26.0	10.4	60.0	16.8
October	22.7	10.6	53.3	19.8
November	27.9	13.2	52.7	18.4
December	26.8	13.6	49.2	19.3



the detection limits (3.1 to 5.0 pCi/L), except for the February sample which was 3.2 pCi/L (Table 9). The gross alpha radioactivity removal efficiency could not be calculated because the raw sewage or effluent radioactivity was below the detection limit. The radioactivity in anaerobically digested sludge ranged from 3.5 to 5.4 pCi/g dw (Table 9).

The gross beta radioactivity levels in the raw sewage of the Hanover Park WRP ranged from 13.0 to 34.0 pCi/L, and in the effluent it ranged from below the detection limit (5.3 pCi/L) to 16.3 pCi/L (Table 10). The gross beta radioactivity removal efficiency of the Hanover Park WRP ranged from 0.7 to 76.2 percent (Table 10). The gross beta radioactivity in the Hanover Park WRP anaerobically digested sludge ranged from 11.4 to 15.9 pCi/g dw (Table 10).

#### James C. Kirie WRP

In 1999, gross alpha radioactivity levels in the raw sewage of the Kirie WRP ranged from below the detection limit (3.6 to 5.3 pCi/L) with the exception of March and April where it was 4.4 and 4.7 pCi/L, respectively. The gross alpha radioactivity in the effluent ranged from below the detection limits (3.1 to 4.0 pCi/L) to 4.7 pCi/L (Table 11). The gross alpha radioactivity in waste-activated sludge ranged from 2.6 to 5.4 pCi/g dw (Table 11).

The gross beta radioactivity level in the raw sewage of Kirie WRP ranged from 15.7 to 30.7 pCi/L, and in the effluent

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 9

GROSS ALPHA RADIOACTIVITY IN HANOVER PARK WRP RAW SEWAGE,  
FINAL EFFLUENT, AND ANAEROBICALLY DIGESTED SLUDGE,  
AND RADIOACTIVITY REMOVAL EFFICIENCY OF THE WRP  
ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Alpha (pCi/L)	Effluent Gross Alpha (pCi/L)	Radioactivity Removal Eff. (%)	Digested Sludge Gross Alpha (pCi/g dw)
January	<5.3	<3.1	*	3.5
February	<3.4	3.2	*	3.7
March	<4.8	<3.2	*	3.7
April	4.1	<3.7	*	3.9
May	<3.6	<3.2	*	4.7
June	<4.1	<3.7	*	5.4
July	<3.9	<3.7	*	3.8
August	<3.6	<3.3	*	4.4
September	<3.5	<3.2	*	3.7
October	<4.3	<3.2	*	5.2
November	<4.7	<5.0	*	4.8
December	<5.2	<3.5	*	5.1

\*Values could not be calculated because the raw sewage or effluent radioactivity was below the detection limit.

< = The quantity listed is the smallest amount that could be measured at 95 percent confidence level (lower limit of detection).

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 10

GROSS BETA RADIOACTIVITY IN HANOVER PARK WRP RAW SEWAGE,  
 FINAL EFFLUENT, AND ANAEROBICALLY DIGESTED SLUDGE,  
 AND RADIOACTIVITY REMOVAL EFFICIENCY OF THE WRP  
 ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Beta (pCi/L)	Effluent Gross Beta (pCi/L)	Radioactivity Removal Eff. (%)	Digested Sludge Gross Beta (pCi/g dw)
January	14.1	9.8	30.5	12.4
February	13.5	8.3	38.5	12.4
March	13.0	10.6	18.4	12.4
April	16.2	14.9	8.0	15.0
May	15.0	14.9	0.7	15.1
June	14.6	<5.3	*	15.9
July	34.0	8.1	76.2	12.7
August	20.7	10.6	48.8	11.9
September	22.0	11.6	51.8	11.8
October	18.1	10.7	40.9	12.0
November	17.3	16.3	5.8	12.5
December	21.8	8.6	60.6	11.4

\*Values could not be calculated because the effluent radioactivity was below the detection limit.

< = The quantity listed is the smallest amount that could be measured at 95 percent confidence level (lower limit of detection).

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 11

GROSS ALPHA RADIOACTIVITY IN JAMES C. KIRIE WRP RAW SEWAGE, FINAL EFFLUENT, AND WASTE-ACTIVATED SLUDGE, AND RADIOACTIVITY REMOVAL EFFICIENCY OF THE WRP ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Alpha (pCi/L)	Effluent Gross Alpha (pCi/L)	Radioactivity Removal Eff. (%)	Waste- Activated Sludge Gross Alpha (pCi/g dw)
January	<3.7	<3.6	*	2.6
February	<4.0	<3.1	*	3.1
March	4.4	<4.0	*	3.2
April	4.7	<3.9	*	3.5
May	<3.7	<3.5	*	4.8
June	<4.2	4.7	*	4.9
July	<3.6	<3.7	*	5.4
August	<4.1	<3.4	*	3.0
September	<3.6	<3.2	*	3.6
October	<4.2	<3.4	*	4.9
November	<4.8	<3.8	*	4.0
December	<5.3	<3.6	*	5.4

\*Values could not be calculated because the raw sewage or effluent radioactivity was below the detection limit.

< = The quantity listed is the smallest amount that could be measured at 95 percent confidence level (lower limit of detection).

it ranged from below the detection limit (5.7 pCi/L) to 20.9 pCi/L (Table 12). The gross beta radioactivity removal efficiency of the Kirie WRP ranged from -18.1 to 47.6 percent (Table 12). The gross beta radioactivity in Kirie WRP waste-activated sludge ranged from 9.3 to 19.8 pCi/g dw (Table 12).

#### Lemont WRP

In 1999, the gross alpha radioactivity levels in the raw sewage of the Lemont WRP ranged from 15.1 to 62.9 pCi/L (Table 13). The gross alpha radioactivity in the effluent was below the detection limit (5.4 to 10.5 pCi/L) (Table 13). The gross alpha radioactivity in the waste-activated sludge ranged from 35.9 to 135.7 pCi/g dw (Table 13).

The gross beta radioactivity levels in the raw sewage of the Lemont WRP ranged from 32.2 to 95.7 pCi/L, and in the effluent it ranged from 11.2 to 36.4 pCi/L (Table 14). The gross beta radioactivity removal efficiency of the Lemont WRP ranged from 34.6 to 81.7 percent. The gross beta radioactivity in Lemont waste-activated sludge ranged from 60.7 to 134.3 pCi/g dw (Table 14).

#### Gross Alpha and Gross Beta Radioactivity in Hanover Park WRP Lagoon Sludge

Table 15 presents the gross alpha and gross beta radioactivity concentration in Hanover Park WRP East and West lagooned sludge.

Average gross alpha radioactivity in Hanover Park East

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 12

GROSS BETA RADIOACTIVITY IN JAMES C. KIRIE WRP RAW SEWAGE, FINAL EFFLUENT, AND WASTE-ACTIVATED SLUDGE, AND RADIOACTIVITY REMOVAL EFFICIENCY OF THE WRP ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Beta (pCi/L)	Effluent Gross Beta (pCi/L)	Radioactivity Removal Eff. (%)	Waste- Activated Sludge Gross Beta (pCi/g dw)
January	17.7	20.9	-18.1	11.0
February	21.0	11.0	47.6	12.4
March	15.7	12.0	23.6	12.1
April	18.8	16.1	14.4	17.2
May	22.5	12.2	45.8	18.1
June	21.8	<5.7	*	19.8
July	18.5	15.6	15.7	16.4
August	30.7	17.6	42.7	9.3
September	22.4	20.6	8.0	12.3
October	21.6	19.7	8.8	11.5
November	22.7	20.7	8.8	10.5
December	22.8	14.4	36.8	13.3

\* Value could not be calculated because the effluent radioactivity was below the detection limit.

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 13

GROSS ALPHA RADIOACTIVITY IN LEMONT WRP RAW SEWAGE,  
FINAL EFFLUENT, AND WASTE-ACTIVATED SLUDGE, AND RADIOACTIVITY  
REMOVAL EFFICIENCY OF THE WRP ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Alpha (pCi/L)	Effluent Gross Alpha (pCi/L)	Radioactivity Removal Eff. (%)	Waste- Activated Sludge Gross Alpha (pCi/g dw)
January	53.8	<6.4	*	35.9
February	22.8	<6.0	*	49.7
March	60.3	<7.0	*	59.3
April	15.1	<5.4	*	58.8
May	17.0	<5.7	*	45.4
June	55.0	<5.5	*	80.6
July	62.9	<6.5	*	84.9
August	30.2	<6.9	*	67.7
September	28.4	<6.9	*	76.0
October	24.4	<6.2	*	126.9
November	24.7	<10.5	*	117.3
December	30.5	<8.4	*	135.7

\*Values could not be calculated because the effluent radioac-  
tivity was below the detection limit.

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 14

GROSS BETA RADIOACTIVITY IN LEMONT WRP RAW SEWAGE,  
FINAL EFFLUENT, AND WASTE-ACTIVATED SLUDGE, AND RADIOACTIVITY  
REMOVAL EFFICIENCY OF THE WRP ON A MONTHLY BASIS - 1999

Month	Raw Sewage Gross Beta (pCi/L)	Effluent Gross Beta (pCi/L)	Radioactivity Removal Eff. (%)	Waste- Activated Sludge Gross Beta (pCi/g dw)
January	69.1	23.6	65.8	60.7
February	47.4	20.6	56.5	98.5
March	66.9	15.1	77.4	76.9
April	32.2	16.5	48.8	95.8
May	36.4	11.2	69.2	70.3
June	80.8	14.8	81.7	113.6
July	95.7	21.9	77.1	131.6
August	52.6	27.8	47.1	91.7
September	55.7	36.4	34.6	118.3
October	51.5	28.2	45.2	134.3
November	51.5	25.7	50.1	112.6
December	69.7	19.5	72.0	125.8



METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 15

GROSS ALPHA AND GROSS BETA RADIOACTIVITY IN HANOVER PARK WRP LAGOONED SLUDGE - 1999

Lagoon Location	No. of Samples	Gross Alpha (pCi/g dw)			Gross Beta (pCi/g dw)		
		Average	Minimum	Maximum	Average	Minimum	Maximum
East	2	6.5	6.4	6.7	15.2	14.5	15.9
West	2	6.5	6.3	6.6	18.1	16.3	19.9

lagooned sludge was 6.5 pCi/g and ranged from 6.4 to 6.7 pCi/g dw. Average gross alpha radioactivity in Hanover Park WRP West lagooned sludge was 6.5 pCi/g, and ranged from 6.3 to 6.6 pCi/g dw.

Average gross beta radioactivity in Hanover Park East lagooned sludge was 15.2 pCi/g, and ranged from 14.5 to 15.9 pCi/g dw. Average gross beta radioactivity in Hanover Park West lagooned sludge was 18.1 pCi/g, and ranged from 16.3 to 19.9 pCi/g dw.

#### Gross Alpha and Gross Beta Radioactivity in District Biosolids

Table 16 presents the gross alpha and gross beta radioactivity concentrations in biosolids samples analyzed from District's sludge management areas.

Average gross alpha radioactivity ranged from 6.0 pCi/g dw at the Vulcan Drying Cells to 7.9 pCi/g dw at the Stony Island Drying Cells. Average gross beta radioactivity ranged from 21.5 pCi/g dw at the LASMA Drying Cells to 28.6 pCi/g dw at the HASMA Drying Cells.

#### Gamma Radioactivity in District WRP Sludges and Biosolids

In 1999, 20 sludge samples from five WRPs, 4 sludge samples from lagoons, and 40 biosolids samples from eight sludge drying sites were analyzed for specific radionuclides. The following is a list of radionuclides monitored:

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 16

GROSS ALPHA AND GROSS BETA RADIOACTIVITY OF DISTRICT BIOSOLIDS - 1999

Sample Location	No. of Samples	Gross Alpha (pCi/g dw)			Gross Beta (pCi/g dw)		
		Average	Minimum	Maximum	Average	Minimum	Maximum
LASMA	5	6.8	5.3	7.8	21.5	14.3	24.1
Calumet East	5	6.9	6.4	7.8	23.7	22.4	25.3
Calumet West	5	7.4	6.2	9.5	24.4	20.9	30.2
HASMA	5	7.4	6.4	10.0	28.6	22.8	45.0
Marathon	5	6.8	6.2	7.2	25.4	21.7	31.0
Stony Island	5	7.9	6.2	9.8	25.0	20.6	28.8
Vulcan	5	6.0	5.2	7.8	22.8	21.9	24.0
RASMA	5	6.7	5.8	7.9	24.6	22.3	27.6

Sodium-22	Barium-133	Gadolinium-153
Potassium-40	Cesium-134	Bismuth-207
Cobalt-57	Cesium-137	Radium-226
Cobalt-60	Antimony-125	Thorium-229
Manganese-54	Zinc-65	Ruthenium-106
Cerium-144	Protactinium-231	Neptunium-237
Silver-108m	Europium-152	Europium-154
Silver-110m	Europium-155	Americium-241

Of the 24 radionuclides analyzed, only 3 (potassium-40, radium-226, and cesium-137) were detected at measurable levels. Of these 3 radionuclides, potassium-40 and radium-226 are of natural origin, and cesium-137 is a man-made radionuclide.

The results of the sludge samples from WRPs, lagoons, and biosolids samples from drying areas are presented in Table 17, 18, and 19, respectively.

Table 17 presents the concentrations of gamma-emitting radionuclides in the sludge from the District WRPs. Average potassium-40 radioactivity ranged from 5.3 pCi/g dw at the Hanover Park WRP to 10.9 pCi/g dw at the Stickney WRP. Average radium-226 radioactivity ranged from 2.1 pCi/g dw at Stickney WRP to 74.6 pCi/g dw at the Lemont WRP. Average cesium-137 radioactivity was not detected at Hanover Park and Lemont WRPs, and was 0.02 pCi/g at the Egan WRP, and 0.1 pCi/g dw at the Calumet and Stickney WRPs.

The village of Lemont uses groundwater for its community

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 17

CONCENTRATION OF GAMMA-EMITTING RADIONUCLIDES IN WRP SLUDGES - 1999

Sample Location - WRP	No. of Samples	Potassium-40 (pCi/g dw)			Radium-226 (pCi/g dw)			Cesium-137 (pCi/g dw)		
		Average	Min.	Max.	Average	Min.	Max.	Average	Min.	Max.
Calumet	4	8.3	6.8	9.8	4.2	3.2	5.4	0.1	0.1	0.1
John E. Egan	4	8.8	7.5	10.9	3.8	2.8	4.9	0.02	ND	0.04
33 Hanover Park	4	5.3	4.6	6.5	3.1	1.9	4.8	ND	ND	ND
Stickney	4	10.9	10.6	11.4	2.1	ND	4.0	0.1	0.1	0.1
Lemont	4	8.3	7.0	10.6	74.6	58.7	86.6	ND	ND	ND

ND = Not detected.

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 18

CONCENTRATION OF GAMMA-EMITTING RADIONUCLIDES IN HANOVER PARK WRP LAGOONED SLUDGE -  
1999

Lagoon Location	No. of Samples	Potassium-40 (pCi/g dw)			Radium-226 (pCi/g dw)			Cesium-137 (pCi/g dw)		
		Ave.	Min.	Max.	Ave.	Min.	Max.	Ave.	Min.	Max.
Hanover Park East	2	5.0	3.1	7.0	4.4	3.4	5.3	0.01	ND	0.02
Hanover Park West	2	4.6	2.9	6.3	4.2	3.4	4.9	0.005	ND	0.01

ND = Not detected.

METROPOLITAN WATER RECLAMATION DISTRICT OF GREATER CHICAGO

TABLE 19

CONCENTRATION OF GAMMA-EMITTING RADIONUCLIDES IN DISTRICT BIOSOLIDS - 1999

Samples Location	No. of Samples	Potassium-40 (pCi/g dw)			Radium-226 (pCi/g dw)			Cesium-137 (pCi/g dw)		
		Ave.	Min.	Max.	Ave.	Min.	Max.	Ave.	Min.	Max.
Calumet East	5	11.3	10.3	13.5	3.8	3.4	4.3	0.1	0.1	0.1
Calumet West	5	9.3	6.5	14.6	4.1	3.1	5.9	0.1	0.1	0.1
RASMA	5	10.9	9.7	12.4	3.6	2.8	4.6	0.1	0.1	0.1
Stony Island	5	10.0	8.4	12.4	3.6	2.7	4.7	0.1	0.1	0.1
HASMA	5	10.6	8.9	12.6	3.5	2.6	4.6	0.1	0.1	0.1
LASMA	5	10.7	8.6	12.6	3.7	2.8	4.4	0.1	0.1	0.1
Marathon	5	10.4	8.7	11.7	3.5	2.6	4.1	0.1	0.1	0.1
Vulcan	5	12.4	9.6	16.9	2.9	2.2	3.4	0.1	0.1	0.1

35

water supply. This groundwater contains naturally occurring radium-226. The village uses an ion exchange system to remove radium-226 from groundwater. The backwash water from the Lemont community water supply system is discharged into the Lemont WRP. The District treats the raw sewage containing this radium-226 at the Lemont WRP to remove contaminants. The radium-226 removed during wastewater treatment process is concentrated in sludge. The Lemont WRP does not have sludge treatment facilities, and it is discharged to either the Calumet or Stickney WRP to be treated at these facilities.

Table 18 presents the concentration of gamma-emitting radionuclides in lagooned sludge. Average potassium-40 radioactivity in Hanover Park WRP East lagooned sludge was 5.0 pCi/g dw (range: 3.1 to 7.0 pCi/g), and in Hanover Park WRP West lagooned sludge, it was 4.6 pCi/g dw (range: 2.9 to 6.3 pCi/g). Average radium-226 radioactivity in Hanover Park WRP East lagooned sludge was 4.4 pCi/g dw (range: 3.4 to 5.3 pCi/g), and in Hanover Park WRP West lagooned sludge it was 4.2 pCi/g dw (range: 3.4 to 4.9 pCi/g). The average cesium-137 activity in Hanover Park WRP East lagooned sludge was 0.01 pCi/g dw (range: ND to 0.02 pCi/g), and in Hanover Park WRP West lagooned sludge the activity was 0.005 pCi/g dw (range: ND to 0.01 pCi/g).

Table 19 presents concentrations of gamma-emitting radionuclides in the District's biosolids. The average potassium-40 activity ranged from 9.3 pCi/g dw in Calumet WRP West bio-



solids to 12.4 pCi/g dw in Vulcan biosolids. The overall concentration range of potassium-40 for District's biosolids was 6.5 to 16.9 pCi/g. The cesium-137 radioactivity was 0.1 pCi/g dw at all the sample locations for all biosolids. Average radium-226 radioactivity ranged from 2.9 pCi/g dw in Vulcan biosolids to 4.1 pCi/g dw in Calumet WRP West biosolids. The overall concentration range of radium-226 for District's biosolids was 2.2 to 5.9 pCi/g.

Currently, there are no USEPA standards for acceptable concentration of radionuclides in sewage sludge and biosolids.

## REFERENCES

1. General Accounting Office, "Nuclear Regulation - Action Needed to Control Radioactive Contamination at Sewage Treatment Plants," Report No. GAO/RCED-94-133, 1994.